

**GLENELG HIGH DRINKING WATER QUALITY REPORT
JANUARY 2025**

Your school’s water is supplied by one or more wells located on school property. The following report is provided by the HCPSS Office of the Environment as a courtesy and is designed to resemble the required annual consumer confidence report provided to consumers by their public water utility/provider informing them about their drinking water. The language used in the report is based on EPA’s Guidance document entitled “Preparing Your Drinking Water Consumer Confidence Report.” Should you have questions or comments, please contact the Office of the Environment at 410-313-8874.

PLEASE NOTE: All sampling results are below Federal and State Safe Drinking Water Standards.

2024 Monitoring Requirements Not Met: We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During September 2024 we did not monitor for disinfection byproducts and therefore cannot be sure of the quality of your drinking water during that time. The sample was collected on November 11, 2024 and the samples met drinking water standards. A public notice was issued on December 20th, 2024. No further action is required at this time.

MONITORING OF SCHOOL’S WATER SUPPLY

Below are the following contaminant categories that are regularly monitored to ensure safe drinking water quality.

Contaminant Category	Current Testing Frequency	Currently Tested By	Last Tested (available)
Bacteria	Monthly	Third Party Water Collector	December 4, 2024
Nitrate	Annually	Third Party Water Collector	January 12, 2024
Metals	Every 3 years	Third Party Water Collector	January 26, 2022
Arsenic	Every 3 years	Third Party Water Collector	January 26, 2022
Volatile Organic Compounds (VOCs) Eg. gasoline	Annually	Maryland Department of the Environment	June 26, 2024
Synthetic Organic Compounds (SOCs) Eg. pesticides	Every 6 years	Maryland Department of the Environment	June 15, 2021
Lead and Copper (L&C)	Every 3 years	HCPSS Certified Water Sampler	September 11, 2024
Disinfection By-Products / Total Trihalomethanes & Haloacetic Acids	Annually	Third Party Water Collector	November 11, 2024

DEFINITIONS

Parts Per Million (ppm) or Milligrams per Liter (mg/l) = a unit used to denote concentration of chemicals or other substances. The unit implies a part of something in one million parts of water or other substances. The following comparisons help in putting this concentration in perspective; 1 inch in 16 miles, 1 cent in \$10,000 or 1 drop in 60 quarts of liquid.

Parts Per Billion (ppb) or Micrograms per Liter (µg/l) = a unit used to denote concentration of chemicals or other substances. The unit implies a part of something in one billion parts of water or other substances. The following comparisons help in putting this concentration in perspective; 1 inch in 16,000 miles, 1 cent in \$10,000,000 or 1 drop in 60,000 quarts of liquid.

Action Level (AL)= the concentration of a contaminant which, if exceeded, triggers treatment or other requirements the water system must follow.

**GLENELG HIGH DRINKING WATER QUALITY REPORT
JANUARY 2025**

Maximum Contaminant Level (MCL) = the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) = the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

EDUCATIONAL INFORMATION

Please note that a public notification is required when a standard is violated and is issued by the Office of the Environment.

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or man-made. The presence of contaminants does not necessarily indicate that the water poses a health risk. Standards are set at very stringent levels for health effects and incorporate a margin of safety. Current standards are designed to protect children and adults. The standards take into account the potential effects of contaminants on segments of the population that are most at risk. **The MCL is based on drinking 2- liters every day at the MCL level for a lifetime (70 years) to have a one-in-a-million chance of having the described health effect.**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

DETECTED CONTAMINANTS w/ MCL/AL (per most recent test) – if a category and/or contaminant is not listed below it means it was not detected during the last test available.

Contaminant	Category	Level Detected	MCL	MCLG	AL	Potential Sources	Potential Health Effects (consuming in excess of MCL)
Lead	Inorganic Chemicals (Lead & Copper)	1.4 µg/l 90 th percentile	N/A	Zero	15 µg/l 90 th percentile	Corrosion of plumbing systems; erosion of natural deposits	Infants and children who drink water containing lead in excess of the action level could experience delays in their physical and mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.
Copper	Inorganic Chemicals (Lead & Copper)	0.34 mg/l 90 th percentile	N/A	1.3 mg/l	1.3 mg/l 90 th percentile	Corrosion of household plumbing; erosion of natural deposits; leaching from wood preservatives	Copper is an essential nutrient, but some people who drink water in excess of AL over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
Nitrate	Inorganic Chemicals	0.8 mg/l	10 mg/l	10 mg/l	N/A	Runoff from fertilizer use; leaching from septic; sewage; erosion of natural deposits	Infants below age 6 months who drink water containing nitrate in excess of MCL could become seriously ill and, if untreated may die. Symptoms include shortness of breath and blue baby syndrome.

**GLENELG HIGH DRINKING WATER QUALITY REPORT
JANUARY 2025**

DETECTED CONTAMINANTS w/ MCL/AL CONTINUED (per most recent test) – if a category and/or contaminant is not listed below it means it was not detected during the last test available.

Contaminant	Category	Level Detected	MCL	MCLG	AL	Potential Sources	Potential Health Effects (consuming in excess of MCL)
Barium	Inorganic Chemicals (Metals)	0.0075 mg/l	2 mg/l	2 mg/l	N/A	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
Chromium	Inorganic Chemicals (Metals)	1.0 µg/l	100 µg/l	100 µg/l	N/A	Discharge from steel and pulp mills; erosion of natural deposits.	Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.
Total Trihalomethanes	Disinfection By-Products	7.1 µg/l	60 µg/l	N/A	N/A	By-product of drinking water disinfection.	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

**GLENELG HIGH DRINKING WATER QUALITY REPORT
JANUARY 2025**

Per- and Polyfluoroalkyl Substances (PFAS)

In preparation for a new federal regulation beginning in 2027, the Maryland Department of the Environment (MDE) and HCPSS proactively began water testing for PFAS (per- and Polyfluoroalkyl Substances) during the Summer of 2024 in our well water schools. PFAS are a series of man-made chemical compounds that persist in the environment for long periods of time. They have long been used in industry and consumer products such as nonstick cookware, waterproof clothing, and stain resistant furniture.

Current scientific research suggests that exposure to certain PFAS may lead to adverse health outcomes. [However, research is still ongoing to determine how differing levels of exposure to different PFAS can lead to a variety of health effects.](#) Because of their widespread application for decades, it is likely most people have been exposed to them during their lifetime.

In preparation for the future regulation, the Maryland Department of the Environment collected preliminary water samples. The results of that sampling event can be found below.

The final EPA rule sets “limits for five individual PFAS: PFOA, PFOS, PFNA, PFHxS, and HFPO-DA. The EPA is also setting a hazard index for two or more of four PFAS as a mixture.” [These four include: PFNA, PFHxS, HFPO-DA, and PFBS](#)

Preliminary PFAS Sample Results (Collected: May 30, 2024)

Facility	PFOA	PFOS	PFBS	PFHxS	PFNA	HEPO-DA	HI
Future MCL (2027)	4.0 ppt	4.0 ppt	N/A	10.0 ppt	10.0 ppt	10.0 ppt	1
Glenelg High School	2.97	2.0	ND	ND	ND	ND	0

ND: None Detected

ppt: parts per trillion

MCL: Maximum Contaminant Level

Hazard index (HI): The hazard index is made up of a sum of fractions. Each fraction compares the level of PFAS measured to a health-based water concentration. More information on calculating the HI.

For additional information: <https://ieq.hcpss.org/pfas>