

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b>	673869	<b>Job Name:</b>	Reservoir High School	<b>Date Submitted:</b>	10/17/2025
<b>Client:</b>	Howard County Public School System	<b>Job Location:</b>	11550 Scaggsville Road, Fulton, MD 20759	<b>Date Analyzed:</b>	10/30/2025
<b>Address:</b>	10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b>	Not Provided	<b>Report Date:</b>	10/31/2025
<b>Attention:</b>	Christopher Madden	<b>P.O. Number:</b>	Not Provided	<b>Date Sampled:</b>	10/15/2025 - 10/16/2025
				<b>Person Submitting:</b>	Chris Madden/John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673869-1	: RHS-1 First Draw	10/15/2025 5:39 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	
673869-2	: RHS-2 First-Draw	10/15/2025 5:40 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.84 ug/L	
673869-3	: RHS-3 First-Draw	10/15/2025 5:41 AM	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle), Yes (= Consumption), Kitchen, See Floor Plan, Kettle, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.6 ug/L	
673869-4	: RHS-4 First-Draw	10/15/2025 5:45 AM	Ice Machine (Stand Alone), Yes (= Consumption), Kitchen, See Floor Plan, Ice Maker, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-5	: RHS-5 First-Draw	10/15/2025 5:43 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.70 ug/L	
673869-6	: RHS-6 First-Draw	10/15/2025 5:34 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-7	: RHS-7 First-Draw	10/16/2025 5:22 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-8	: RHS-8 First-Draw	10/15/2025 5:33 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-9	: RHS-9 First-Draw	10/15/2025 5:32 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-10	: RHS-10F First-Draw	10/15/2025 5:29 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-11	: RHS-10S First-Draw	10/16/2025 5:24 AM	Combination Sink - Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.83 ug/L	
673869-12	: RHS-11 First-Draw	10/15/2025 5:30 AM	Faucet, Cold, Yes (= Consumption), Hallway, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-13	: RHS-12 First-Draw	10/15/2025 5:28 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.86 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b>	673869	<b>Job Name:</b>	Reservoir High School	<b>Date Submitted:</b>	10/17/2025
<b>Client:</b>	Howard County Public School System	<b>Job Location:</b>	11550 Scaggsville Road, Fulton, MD 20759	<b>Date Analyzed:</b>	10/30/2025
<b>Address:</b>	10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b>	Not Provided	<b>Report Date:</b>	10/31/2025
<b>Attention:</b>	Christopher Madden	<b>P.O. Number:</b>	Not Provided	<b>Date Sampled:</b>	10/15/2025 - 10/16/2025
				<b>Person Submitting:</b>	Chris Madden/John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673869-14	: RHS-13 First-Draw	10/15/2025 5:26 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Staff Workroom, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.57 ug/L	
673869-15	: RHS-14 First-Draw	10/15/2025 5:00 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-16	: RHS-14BW First-Draw	10/16/2025 5:06 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-18	: RHS-16 First-Draw	10/15/2025 5:01 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-19	: RHS-17 First-Draw	10/15/2025 5:04 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Weight/Training/Fitness Room, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-20	: RHS-18 First-Draw	10/15/2025 5:06 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Multi Purpose Room, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.63 ug/L	
673869-21	: RHS-18BW First-Draw	10/16/2025 5:05 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Multi Purpose Room, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.59 ug/L	
673869-22	: RHS-20 First-Draw	10/15/2025 5:08 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.94 ug/L	
673869-23	: RHS-21 First-Draw	10/16/2025 5:09 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	
673869-24	: RHS-22 First-Draw	10/15/2025 5:10 AM	Faucet, Cold, Yes (= Consumption), Concessions, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.55 ug/L	
673869-25	: RHS-23 First-Draw	10/15/2025 5:11 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Locker Room, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.54 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b>	673869	<b>Job Name:</b>	Reservoir High School	<b>Date Submitted:</b>	10/17/2025
<b>Client:</b>	Howard County Public School System	<b>Job Location:</b>	11550 Scaggsville Road, Fulton, MD 20759	<b>Date Analyzed:</b>	10/30/2025
<b>Address:</b>	10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b>	Not Provided	<b>Report Date:</b>	10/31/2025
<b>Attention:</b>	Christopher Madden	<b>P.O. Number:</b>	Not Provided	<b>Date Sampled:</b>	10/15/2025 - 10/16/2025
				<b>Person Submitting:</b>	Chris Madden/John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673869-26	: RHS-24 First-Draw	10/15/2025 5:16 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-27	: RHS-24BW First-Draw	10/16/2025 5:12 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-28	: RHS-25 First-Draw	10/15/2025 5:14 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Locker Room, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-29	: RHS-26 First-Draw	10/15/2025 5:17 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-30	: RHS-27 First-Draw	10/15/2025 5:21 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-31	: RHS-27BW First-Draw	10/15/2025 5:14 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-32	: RHS-28 First-Draw	10/15/2025 5:23 AM	Ice Machine (Stand Alone), Yes (= Consumption), Weight/Training/Fitness Room, See Floor Plan, Ice Maker, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-33	: RHS-32 First-Draw	10/15/2025 5:18 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-34	: RHS-33 First-Draw	10/15/2025 5:24 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-35	: RHS-36 First-Draw	10/15/2025 5:46 AM	Drinking Water Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Outdoors, See Floor Plan, Bubbler, Main Bldg, Ground Floor	ICP	Lead	0.5 ug/L	2.7 ug/L	
673869-36	: RHS-42 First-Draw	10/15/2025 5:19 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b>	673869	<b>Job Name:</b>	Reservoir High School	<b>Date Submitted:</b>	10/17/2025
<b>Client:</b>	Howard County Public School System	<b>Job Location:</b>	11550 Scaggsville Road, Fulton, MD 20759	<b>Date Analyzed:</b>	10/30/2025
<b>Address:</b>	10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b>	Not Provided	<b>Report Date:</b>	10/31/2025
<b>Attention:</b>	Christopher Madden	<b>P.O. Number:</b>	Not Provided	<b>Date Sampled:</b>	10/15/2025 - 10/16/2025
				<b>Person Submitting:</b>	Chris Madden/John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673869-37	: RHS-44 First-Draw	10/15/2025 5:22 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-38	: RHS-45 First-Draw	10/15/2025 5:23 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	0.51 ug/L	
673869-39	: RHS-46 First-Draw	10/15/2025 5:24 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	0.83 ug/L	
673869-40	: RHS-47 First-Draw	10/15/2025 5:25 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	0.58 ug/L	
673869-41	: RHS-48 First-Draw	10/15/2025 5:26 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-42	: RHS-49 First-Draw	10/15/2025 5:27 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-43	: RHS-50 First-Draw	10/15/2025 5:28 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-44	: RHS-51 First-Draw	10/15/2025 5:29 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	0.62 ug/L	
673869-45	: RHS-52 First-Draw	10/15/2025 5:35 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-46	: RHS-57 First-Draw	10/15/2025 5:11 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-47	: RHS-58 First-Draw	10/15/2025 5:13 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b>	673869	<b>Job Name:</b>	Reservoir High School	<b>Date Submitted:</b>	10/17/2025
<b>Client:</b>	Howard County Public School System	<b>Job Location:</b>	11550 Scaggsville Road, Fulton, MD 20759	<b>Date Analyzed:</b>	10/30/2025
<b>Address:</b>	10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b>	Not Provided	<b>Report Date:</b>	10/31/2025
<b>Attention:</b>	Christopher Madden	<b>P.O. Number:</b>	Not Provided	<b>Date Sampled:</b>	10/15/2025 - 10/16/2025
				<b>Person Submitting:</b>	Chris Madden/John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673869-48	: RHS-58BW First-Draw	10/16/2025 5:27 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-49	: RHS-59 First-Draw	10/15/2025 5:16 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Media Center, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-50	: RHS-60F First-Draw	10/15/2025 5:14 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	0.61 ug/L	
673869-51	: RHS-62 First-Draw	10/15/2025 5:03 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-52	: RHS-63 First-Draw	10/16/2025 5:28 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-53	: RHS-65 First-Draw	10/15/2025 5:01 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-54	: RHS-66 First-Draw	10/15/2025 5:00 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-55	: RHS-68 First-Draw	10/15/2025 5:05 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-56	: RHS-69 First-Draw	10/16/2025 5:34 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-57	: RHS-70 First-Draw	10/15/2025 5:04 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-58	: RHS-70BW First-Draw	10/16/2025 5:30 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 3rd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b>	673869	<b>Job Name:</b>	Reservoir High School	<b>Date Submitted:</b>	10/17/2025
<b>Client:</b>	Howard County Public School System	<b>Job Location:</b>	11550 Scaggsville Road, Fulton, MD 20759	<b>Date Analyzed:</b>	10/30/2025
<b>Address:</b>	10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b>	Not Provided	<b>Report Date:</b>	10/31/2025
<b>Attention:</b>	Christopher Madden	<b>P.O. Number:</b>	Not Provided	<b>Date Sampled:</b>	10/15/2025 - 10/16/2025
				<b>Person Submitting:</b>	Chris Madden/John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673869-59	: RHS-71 First-Draw	10/15/2025 5:57 AM	Faucet, Cold, Yes (= Consumption), Concessions, See Floor Plan, Sink, Concession Stand, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-60	: RHS-72 First-Draw	10/15/2025 5:58 AM	Spigot (with threadings for hose connection), Yes (= Consumption), Concessions, See Floor Plan, Spigot, Concession Stand, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-61	: RHS-73 First-Draw	10/16/2025 5:15 AM	Faucet, Cold, Yes (= Consumption), Weight/Training/Fitness Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673869-62	: RHS-1 Flush	10/15/2025 4:57:00 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.
673869-63	: RHS-2 Flush	10/15/2025 4:58:00 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.
673869-64	: RHS-5 Flush	10/15/2025 5:00:00 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)

Preparation Method: None

mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

**Analyst(s):** JP Littleton

Sample Collector: Christopher Madden and John Farmer

Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.



**Technical Director** George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.