

CERTIFICATE OF ANALYSIS

Chain of Custody:	673870	Job Name:	Thomas Viaduct Middle School	Date Submitted:	10/17/2025
Client:	Howard County Public School System	Job Location:	70000 Banbury Drive, Hanover MD 21076	Date Analyzed:	10/30/2025
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/31/2025
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	10/09/2025 - 10/17/2025
				Person Submitting:	Christopher Madden

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673870-1	: TVMS-1 First Draw	10/09/2025 5:28 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-2	: TVMS-3F First Draw	10/09/2025 5:31 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-3	: TVMS-3S First Draw	10/10/2025 5:51 AM	Combination Sink - Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-4	: TVMS-4 First Draw	10/09/2025 5:33 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-5	: TVMS-8F First Draw	10/09/2025 5:36 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-6	: TVMS-9 First Draw	10/09/2025 5:41 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-7	: TVMS-10F First Draw	10/09/2025 5:37 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-8	: TVMS-11F First Draw	10/09/2025 5:42 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-9	: TVMS-12 First Draw	10/09/2025 5:45 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-10	: TVMS-14 First Draw	10/09/2025 5:54 AM	Refrigerator Water Dispenser -- Not required if non-metal water line, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Dispenser, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-11	: TVMS-15 First Draw	10/09/2025 5:55 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody:	673870	Job Name:	Thomas Viaduct Middle School	Date Submitted:	10/17/2025
Client:	Howard County Public School System	Job Location:	70000 Banbury Drive, Hanover MD 21076	Date Analyzed:	10/30/2025
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/31/2025
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	10/09/2025 - 10/17/2025
				Person Submitting:	Christopher Madden

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673870-12	: TVMS-16 First Draw	10/09/2025 5:56 AM	Refrigerator Water Dispenser -- Not required if non-metal water line, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Dispenser, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-13	: TVMS-17 First Draw	10/09/2025 5:57 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-14	: TVMS-18 First Draw	10/09/2025 5:57 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-15	: TVMS-19 First Draw	10/09/2025 5:58 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-16	: TVMS-20 First Draw	10/09/2025 5:59 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-17	: TVMS-21 First Draw	10/09/2025 6:00 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-18	: TVMS-22 First Draw	10/09/2025 6:01 AM	Refrigerator Water Dispenser -- Not required if non-metal water line, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Dispenser, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-19	: TVMS-23 First Draw	10/09/2025 6:03 AM	Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-20	: TVMS-25 First Draw	10/09/2025 6:04 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-21	: TVMS-25BW First Draw	10/17/2025 6:01 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-22	: TVMS-26 First Draw	10/10/2025 5:53 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (=	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody:	673870	Job Name:	Thomas Viaduct Middle School	Date Submitted:	10/17/2025
Client:	Howard County Public School System	Job Location:	70000 Banbury Drive, Hanover MD 21076	Date Analyzed:	10/30/2025
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/31/2025
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	10/09/2025 - 10/17/2025
				Person Submitting:	Christopher Madden

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
			Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor					
673870-23	: TVMS-27 First Draw	10/09/2025 6:06 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Locker Room, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-24	: TVMS-28 First Draw	10/09/2025 6:07 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Locker Room, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-25	: TVMS-29 First Draw	10/09/2025 6:09 AM	Ice Machine (Stand Alone), Yes (= Consumption), Kitchen, See Floor Plan, Ice Maker, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-26	: TVMS-30 First Draw	10/09/2025 6:10 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	
673870-27	: TVMS-32 First Draw	10/09/2025 6:13 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-28	: TVMS-33 First Draw	10/09/2025 6:15 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-29	: TVMS-35F First Draw	10/09/2025 6:19 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-30	: TVMS-36F First Draw	10/09/2025 6:20 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-31	: TVMS-37F First Draw	10/09/2025 6:22 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-32	: TVMS-38 First Draw	10/09/2025 6:23 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-33	: TVMS-42 First Draw	10/09/2025 6:24 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

CERTIFICATE OF ANALYSIS

Chain of Custody:	673870	Job Name:	Thomas Viaduct Middle School	Date Submitted:	10/17/2025
Client:	Howard County Public School System	Job Location:	70000 Banbury Drive, Hanover MD 21076	Date Analyzed:	10/30/2025
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/31/2025
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	10/09/2025 - 10/17/2025
				Person Submitting:	Christopher Madden

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
673870-34	: TVMS-44 First Draw	10/09/2025 6:26 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
673870-35	: TVMS--30 Flush	10/17/2025 5:07:00 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.
673870-36	: TVMS-32 Flush	10/17/2025 5:05:00 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.
673870-37	: TVMS-33 Flush	10/17/2025 5:04:00 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)
Preparation Method: None
mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

Sample Collector: Christopher Madden
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Analyst(s): JP Littleton



Technical Director George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.

CERTIFICATE OF ANALYSIS

Chain of Custody:	674905	Job Name:	Thomas Viaduct Middle School	Date Submitted:	11/24/2025
Client:	Howard County Public School System	Job Location:	7000 Banbury Drive, Hanover, MD 21076	Date Analyzed:	11/25/2025
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	11/25/2025
Attention:	Christopher Madden	P.O. Number:	Not Provided	Date Sampled:	11/20/2025
				Person Submitting:	Christopher Madden

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
674905-1	: TVMS-5 First Draw	11/20/2025 6:21 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.92 ug/L	
674905-2	: TVMS-13 First Draw	11/20/2025 6:22 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)

Preparation Method: None

mg/L = Parts Per Million (ppm), N/A = Not Applicable, ug/L = Parts Per Billion, N/P = Not Provided

Analyst(s): JP Littleton

Sample Collector: Christopher Madden
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Technical Director _____
George Land



This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.