

CERTIFICATE OF ANALYSIS

| | | | | | |
|--------------------------|--|----------------------|--|---------------------------|--------------------------|
| Chain of Custody: | 674610 | Job Name: | Wilde Lake Middle School | Date Submitted: | 11/12/2025 |
| Client: | Howard County Public School System | Job Location: | 5460 Trumpeter Road, Columbia, MD 21044 | Date Analyzed: | 12/02/2025 |
| Address: | 10910 Clarksville Pike Ellicott City MD 21042 | Job Number: | 13.058 | Report Date: | 12/02/2025 |
| Attention: | Christopher Madden | P.O. Number: | Not Provided | Date Sampled: | 11/05/2025 - 11/12/2025 |
| | | | | Person Submitting: | Joel Ortiz |
| | | | | Revised: | 12/03/2025 (Revision #1) |

Summary of Drinking Water Analysis for Metals

| AMA Sample Number | Client Sample Number | Date/Time | Location | Analysis Type | Sample Analyte | Reporting Limit | Final Result | Comments |
|-------------------|-----------------------|--------------------|---|---------------|----------------|-----------------|--------------|----------|
| 674610-1 | : WLMS-1 First Draw | 11/07/2025 5:44 AM | Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-2 | : WLMS-2 First Draw | 11/07/2025 5:46 AM | Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-3 | : WLMS-3 First Draw | 11/07/2025 5:47 AM | Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-4 | : WLMS-4 First Draw | 11/07/2025 5:48 AM | Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-5 | : WLMS-5 First Draw | 11/07/2025 5:49 AM | Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-6 | : WLMS-6 First Draw | 11/07/2025 5:50 AM | Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-7 | : WLMS-7 First Draw | 11/07/2025 5:51 AM | Faucet, Cold, Yes (= Consumption), Classroom (Home Economics), See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-8 | : WLMS-8 First Draw | 11/07/2025 5:42 AM | Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-9 | : WLMS-9 First Draw | 11/07/2025 5:40 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-10 | : WLMS-9BW First Draw | 11/12/2025 5:31 AM | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-11 | : WLMS-10 First Draw | 11/05/2025 6:47 AM | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-12 | : WLMS-11 First Draw | 11/07/2025 5:39 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |

CERTIFICATE OF ANALYSIS

| | | | | | |
|--------------------------|--|----------------------|--|---------------------------|--------------------------|
| Chain of Custody: | 674610 | Job Name: | Wilde Lake Middle School | Date Submitted: | 11/12/2025 |
| Client: | Howard County Public School System | Job Location: | 5460 Trumpeter Road, Columbia, MD 21044 | Date Analyzed: | 12/02/2025 |
| Address: | 10910 Clarksville Pike Ellicott City MD 21042 | Job Number: | 13.058 | Report Date: | 12/02/2025 |
| Attention: | Christopher Madden | P.O. Number: | Not Provided | Date Sampled: | 11/05/2025 - 11/12/2025 |
| | | | | Person Submitting: | Joel Ortiz |
| | | | | Revised: | 12/03/2025 (Revision #1) |

Summary of Drinking Water Analysis for Metals

| AMA Sample Number | Client Sample Number | Date/Time | Location | Analysis Type | Sample Analyte | Reporting Limit | Final Result | Comments |
|-------------------|------------------------|--------------------|---|---------------|----------------|-----------------|--------------|----------|
| 674610-13 | : WLMS-11BW First Draw | 11/12/2025 5:32 AM | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Cafeteria, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-14 | : WLMS-12 First Draw | 11/07/2025 5:37 AM | Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-15 | : WLMS-13 First Draw | 11/07/2025 5:36 AM | Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-16 | : WLMS-14 First Draw | 11/07/2025 5:34 AM | Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-17 | : WLMS-15 First Draw | 11/07/2025 5:53 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Locker Room, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-18 | : WLMS-15BW First Draw | 11/12/2025 5:53 AM | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Locker Room, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-19 | : WLMS-16 First Draw | 11/07/2025 5:54 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Locker Room, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-20 | : WLMS-17 First Draw | 11/07/2025 5:56 AM | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-21 | : WLMS-23 First Draw | 11/07/2025 6:01 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-22 | : WLMS-23BW First Draw | 11/12/2025 5:39 AM | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-23 | : WLMS-30 First Draw | 11/07/2025 6:14 AM | Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-24 | : WLMS-31F First Draw | 11/07/2025 6:12 AM | Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Bubbler, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |

CERTIFICATE OF ANALYSIS

| | | | | | |
|--------------------------|--|----------------------|--|---------------------------|--------------------------|
| Chain of Custody: | 674610 | Job Name: | Wilde Lake Middle School | Date Submitted: | 11/12/2025 |
| Client: | Howard County Public School System | Job Location: | 5460 Trumpeter Road, Columbia, MD 21044 | Date Analyzed: | 12/02/2025 |
| Address: | 10910 Clarksville Pike Ellicott City MD 21042 | Job Number: | 13.058 | Report Date: | 12/02/2025 |
| Attention: | Christopher Madden | P.O. Number: | Not Provided | Date Sampled: | 11/05/2025 - 11/12/2025 |
| | | | | Person Submitting: | Joel Ortiz |
| | | | | Revised: | 12/03/2025 (Revision #1) |

Summary of Drinking Water Analysis for Metals

| AMA Sample Number | Client Sample Number | Date/Time | Location | Analysis Type | Sample Analyte | Reporting Limit | Final Result | Comments |
|-------------------|------------------------|--------------------|---|---------------|----------------|-----------------|--------------|---|
| 674610-25 | : WLMS-31S First Draw | 11/12/2025 5:43 AM | Combination Sink - Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-26 | : WLMS-32 First Draw | 11/07/2025 6:04 AM | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-27 | : WLMS-33F First Draw | 11/07/2025 6:06 AM | Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 2nd Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-28 | : WLMS-34 First Draw | 11/07/2025 6:07 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-29 | : WLMS-34BW First Draw | 11/12/2025 5:47 AM | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 2nd Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-30 | : WLMS-37 First Draw | 11/07/2025 6:08 AM | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-31 | : WLMS-38 First Draw | 11/07/2025 6:10 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-32 | : WLMS-38BW First Draw | 11/12/2025 5:45 AM | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 2nd Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-33 | : WLMS-29 First-Draw | 11/07/2025 6:03 AM | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-34 | : WLMS-29BW First-Draw | 11/12/2025 5:41 AM | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |
| 674610-35 | : WLMS-12 Flush | 11/12/2025 5:54 AM | Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor | | | | | Void: Sample not analyzed, associated 1st draw <5.5ppb. |
| 674610-36 | : WLMS-13 Flush | 11/12/2025 5:53 AM | Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor | | | | | Void: Sample not analyzed, associated 1st draw <5.5ppb. |

CERTIFICATE OF ANALYSIS

| | | | | | |
|--------------------------|--|----------------------|--|---------------------------|--------------------------|
| Chain of Custody: | 674610 | Job Name: | Wilde Lake Middle School | Date Submitted: | 11/12/2025 |
| Client: | Howard County Public School System | Job Location: | 5460 Trumpeter Road, Columbia, MD 21044 | Date Analyzed: | 12/02/2025 |
| Address: | 10910 Clarksville Pike Ellicott City MD 21042 | Job Number: | 13.058 | Report Date: | 12/02/2025 |
| Attention: | Christopher Madden | P.O. Number: | Not Provided | Date Sampled: | 11/05/2025 - 11/12/2025 |
| | | | | Person Submitting: | Joel Ortiz |
| | | | | Revised: | 12/03/2025 (Revision #1) |

Summary of Drinking Water Analysis for Metals

| AMA Sample Number | Client Sample Number | Date/Time | Location | Analysis Type | Sample Analyte | Reporting Limit | Final Result | Comments |
|-------------------|----------------------|--------------------|---|---------------|----------------|-----------------|--------------|---|
| 674610-37 | : WLMS-14 Flush | 11/12/2025 5:52 AM | Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor | | | | | Void: Sample not analyzed, associated 1st draw <5.5ppb. |
| 674610-38 | : WLMS-28 First-Draw | 11/07/2025 6:01 AM | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor | ICP | Lead | 0.5 ug/L | <0.5 ug/L | |

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)

Preparation Method: None

mg/L = Parts Per Million (ppm), N/A = Not Applicable, ug/L = Parts Per Billion, N/P = Not Provided

 Sample Collector: Christopher Madden
 Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Analyst(s): JP Littleton



 Technical
 Director

JP Littleton

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.