

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b> 678549	<b>Job Name:</b> Veterans Elementary School	<b>Date Submitted:</b> 03/27/2026
<b>Client:</b> Howard County Public School System	<b>Job Location:</b> 4355 Montgomery Road, Ellicott City, MD 21043	<b>Date Analyzed:</b> 04/01/2026
<b>Address:</b> 10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b> Not Provided	<b>Report Date:</b> 04/02/2026
<b>Attention:</b> Christopher Madden	<b>P.O. Number:</b> Not Provided	<b>Date Sampled:</b> 03/17/2026 - 03/18/2026
		<b>Person Submitting:</b> John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
678549-1	: VES-01 First-Draw	03/18/2026 5:08 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	2.1 ug/L	
678549-2	: VES-2 First-Draw	03/17/2026 5:51 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Cafeteria, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-3	: VES-2BW First-Draw	03/18/2026 5:05 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Cafeteria, See Floor Plan, Bottle Filler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-4	: VES-3 First-Draw	03/18/2026 5:04 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-5	: VES-4 First-Draw	03/17/2026 5:50 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-6	: VES-5F First-Draw	03/17/2026 5:49 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-7	: VES-6F First-Draw	03/17/2026 5:48 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-8	: VES-7F First-Draw	03/17/2026 5:47 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-9	: VES-8F First-Draw	03/17/2026 5:46 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-10	: VES-9F First-Draw	03/17/2026 5:45 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-11	: VES-10 First-Draw	03/17/2026 5:42 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-12	: VES-11 First-Draw	03/17/2026 5:41 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, See Floor Plan, Sink, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-13	: VES-12F First-Draw	03/17/2026 5:40 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b> 678549	<b>Job Name:</b> Veterans Elementary School	<b>Date Submitted:</b> 03/27/2026
<b>Client:</b> Howard County Public School System	<b>Job Location:</b> 4355 Montgomery Road, Ellicott City, MD 21043	<b>Date Analyzed:</b> 04/01/2026
<b>Address:</b> 10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b> Not Provided	<b>Report Date:</b> 04/02/2026
<b>Attention:</b> Christopher Madden	<b>P.O. Number:</b> Not Provided	<b>Date Sampled:</b> 03/17/2026 - 03/18/2026
		<b>Person Submitting:</b> John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
678549-14	: VES-13F First-Draw	03/17/2026 5:39 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-15	: VES-14F First-Draw	03/17/2026 5:38 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-16	: VES-15F First-Draw	03/17/2026 5:37 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-17	: VES-16 First-Draw	03/17/2026 5:36 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-18	: VES-17F First-Draw	03/17/2026 5:34 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-19	: VES-18F First-Draw	03/17/2026 5:32 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-20	: VES-19F First-Draw	03/17/2026 5:31 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-21	: VES-20F First-Draw	03/17/2026 5:30 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-22	: VES-22F First-Draw	03/17/2026 5:26 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-23	: VES-23F First-Draw	03/17/2026 5:25 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-24	: VES-24F First-Draw	03/17/2026 5:14 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-25	: VES-25 First-Draw	03/17/2026 5:15 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-26	: VES-26 First-Draw	03/17/2026 5:17 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, See Floor Plan, Sink, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b> 678549	<b>Job Name:</b> Veterans Elementary School	<b>Date Submitted:</b> 03/27/2026
<b>Client:</b> Howard County Public School System	<b>Job Location:</b> 4355 Montgomery Road, Ellicott City, MD 21043	<b>Date Analyzed:</b> 04/01/2026
<b>Address:</b> 10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b> Not Provided	<b>Report Date:</b> 04/02/2026
<b>Attention:</b> Christopher Madden	<b>P.O. Number:</b> Not Provided	<b>Date Sampled:</b> 03/17/2026 - 03/18/2026
		<b>Person Submitting:</b> John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
678549-27	: VES-28F First-Draw	03/17/2026 5:24 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-28	: VES-29 First-Draw	03/17/2026 5:23 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-29	: VES-30F First-Draw	03/17/2026 5:22 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-30	: VES-31F First-Draw	03/17/2026 5:20 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-31	: VES-32F First-Draw	03/17/2026 5:19 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-32	: VES-33F First-Draw	03/17/2026 5:18 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-33	: VES-34F First-Draw	03/17/2026 5:13 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-34	: VES-35F First-Draw	03/17/2026 5:12 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-35	: VES-36F First-Draw	03/17/2026 5:10 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-36	: VES-37F First-Draw	03/17/2026 5:09 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-37	: VES-38 First-Draw	03/17/2026 5:55 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-38	: VES-39 First-Draw	03/17/2026 5:56 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, See Floor Plan, Sink, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-39	: VES-41F First-Draw	03/17/2026 5:59 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b> 678549	<b>Job Name:</b> Veterans Elementary School	<b>Date Submitted:</b> 03/27/2026
<b>Client:</b> Howard County Public School System	<b>Job Location:</b> 4355 Montgomery Road, Ellicott City, MD 21043	<b>Date Analyzed:</b> 04/01/2026
<b>Address:</b> 10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b> Not Provided	<b>Report Date:</b> 04/02/2026
<b>Attention:</b> Christopher Madden	<b>P.O. Number:</b> Not Provided	<b>Date Sampled:</b> 03/17/2026 - 03/18/2026
		<b>Person Submitting:</b> John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
678549-40	: VES-42 First-Draw	03/17/2026 5:54 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-41	: VES-45 First-Draw	03/18/2026 5:01 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-42	: VES-46 First-Draw	03/17/2026 5:53 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-43	: VES-47 First-Draw	03/17/2026 6:00 AM	Faucet, Cold, Yes (= Consumption), Media Center, See Floor Plan, Sink, Main Bldg, 1st Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-44	: VES-49 First-Draw	03/17/2026 6:03 AM	Faucet, Cold, Yes (= Consumption), Teachers' Lounge/Break Room, See Floor Plan, Sink, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-45	: VES-57 First-Draw	03/17/2026 6:08 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-46	: VES-58 First-Draw	03/17/2026 6:07 AM	Faucet, Cold, Yes (= Consumption), Classroom, See Floor Plan, Sink, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-47	: VES-63 First-Draw	03/17/2026 6:09 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-48	: VES-70 First-Draw	03/17/2026 6:24 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-49	: VES-76 First-Draw	03/17/2026 6:15 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-50	: VES-77 First-Draw	03/17/2026 6:16 AM	Faucet, Cold, Yes (= Consumption), Classroom, See Floor Plan, Sink, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-51	: VES-84 First-Draw	03/18/2026 5:14 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-52	: VES-85 First-Draw	03/17/2026 6:22 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	

## CERTIFICATE OF ANALYSIS

<b>Chain of Custody:</b> 678549	<b>Job Name:</b> Veterans Elementary School	<b>Date Submitted:</b> 03/27/2026
<b>Client:</b> Howard County Public School System	<b>Job Location:</b> 4355 Montgomery Road, Ellicott City, MD 21043	<b>Date Analyzed:</b> 04/01/2026
<b>Address:</b> 10910 Clarksville Pike Ellicott City MD 21042	<b>Job Number:</b> Not Provided	<b>Report Date:</b> 04/02/2026
<b>Attention:</b> Christopher Madden	<b>P.O. Number:</b> Not Provided	<b>Date Sampled:</b> 03/17/2026 - 03/18/2026
		<b>Person Submitting:</b> John Farmer

### Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
678549-53	: VES-88 First-Draw	03/18/2026 5:12 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-54	: VES-89 First-Draw	03/17/2026 6:06 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 2nd Floor	Furnace AA	Lead	2 ug/L	<2 ug/L	
678549-55	: VES-01 Flush	03/18/2026 4:18 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.

Analysis Method: APHA SM 3113B (GFAA)  
Preparation Method: None  
mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

Sample Collector: John Farmer  
Certification:

**Analyst(s):** Nida Mcgarvey

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.



**Technical Director** \_\_\_\_\_  
George Land

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. The results apply only to the sample(s) tested as received. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.