



CERTIFICATE OF ANALYSIS

Chain of Custody:	685087	Job Name:	Bryant Woods Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	5450 Blue Heron Lane, Columbia MD 21044	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/23/2026 - 09/30/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685087-1	: BWES-2 First Draw	09/23/2026 5:48 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-2	: BWES-1A First Draw	09/25/2026 5:45 AM	Multiple Compartment Sink - Faucet, Cold, Yes (= Consumption), Kitchen, SEE MAP, LEFT SINK, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.62 ug/L	
685087-3	: BWES-1B First Draw	09/23/2026 5:52 AM	Multiple Compartment Sink - Faucet, Cold, Yes (= Consumption), Kitchen, SEE MAP, RIGHT SINK, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.0 ug/L	
685087-4	: BWES-3 First Draw	09/23/2026 5:43 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, SEE MAP, FAUCET, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.63 ug/L	
685087-5	: BWES-4 First Draw	09/25/2026 5:40 AM	Drinking Water Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-6	: BWES-5 First Draw	09/23/2026 5:42 AM	Drinking Water Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-7	: BWES-6F First Draw	09/30/2026 6:33 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	
685087-8	: BWES-8F First Draw	09/30/2026 6:34 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.8 ug/L	
685087-9	: BWES-9F First Draw	09/23/2026 5:41 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.73 ug/L	
685087-10	: BWES-10F First Draw	09/23/2026 5:40 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.57 ug/L	
685087-11	: BWES-11F First Draw	09/23/2026 5:32 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-12	: BWES-12F First Draw	09/23/2026 5:31 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody:	685087	Job Name:	Bryant Woods Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	5450 Blue Heron Lane, Columbia MD 21044	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/23/2026 - 09/30/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685087-13	: BWES-13F First Draw	09/23/2026 5:30 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	4.7 ug/L	
685087-14	: BWES-14F First Draw	09/23/2026 5:29 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-15	: BWES-15F First Draw	09/30/2026 6:30 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.0 ug/L	
685087-16	: BWES-17 First Draw	09/23/2026 5:35 AM	Drinking Water Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-17	: BWES-18 First Draw	09/25/2026 5:37 AM	Drinking Water Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-18	: BWES-19 First Draw	09/23/2026 5:25 AM	Drinking Water Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-19	: BWES-20F First Draw	09/23/2026 5:24 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.7 ug/L	
685087-20	: BWES-21F First Draw	09/23/2026 5:21 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.65 ug/L	
685087-21	: BWES-24F First Draw	09/23/2026 5:19 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-22	: BWES-25F First Draw	09/23/2026 5:18 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-23	: BWES-26F First Draw	09/30/2026 6:27 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
685087-24	: BWES-29F First Draw	09/30/2026 6:26 AM	Combination Sink - Fountain - bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	6.8 ug/L	This result meets or exceeds the 5.5ppb action level as established by MDE for schools.



CERTIFICATE OF ANALYSIS

Chain of Custody:	685087	Job Name:	Bryant Woods Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	5450 Blue Heron Lane, Columbia MD 21044	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/23/2026 - 09/30/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685087-25	: BWES-30F First Draw	09/23/2026 5:07 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.60 ug/L	
685087-26	: BWES-31F First Draw	09/23/2026 5:05 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-27	: BWES-32F First Draw	09/23/2026 5:04 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-28	: BWES-27 First Draw	09/23/2026 5:13 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-29	: BWES-28 First Draw	09/25/2026 5:35 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-30	: BWES-34F First Draw	09/23/2026 5:01 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.8 ug/L	
685087-31	: BWES-37F First Draw	09/23/2026 5:00 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-32	: BWES-33 First-Draw	09/23/2026 5:12 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, SEE MAP, FAUCET, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.0 ug/L	
685087-33	: BWES-35 First-Draw	09/23/2026 5:49 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-34	: BWES-36 First-Draw	09/30/2026 6:37 AM	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, SEE MAP, BUBBLER, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-35	: BWES-2BW First-Draw	09/25/2026 5:42 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, SEE MAP, BOTTLE FILL, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody:	685087	Job Name:	Bryant Woods Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	5450 Blue Heron Lane, Columbia MD 21044	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/23/2026 - 09/30/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685087-36	: BWES-35BW First-Draw	09/25/2026 5:44 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, SEE MAP, BOTTLE FILL, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685087-37	: BWES-1B Flush	09/23/2026 4:54 AM	Faucet, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Righ Sink, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)

Preparation Method: None

mg/L = Parts Per Million (ppm), N/A = Not Applicable, ug/L = Parts Per Billion, N/P = Not Provided

Sample Collector: John Farmer

Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Analyst(s): JP Littleton

Technical
Director George Land

This report applies only to the sample(s) investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter, nor shall it be reproduced, except in full, without prior written authorization from us. Sample types, locations, collection protocols, air volumes and/or surface wipe area measurements are based upon information provided by the person(s) submitting them, and unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information and for analytical results calculated based on this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA LAP, NVLAP, NIST, or any agency of the Federal Government. All rights reserved. SGS AMA Analytical Services, Inc.