



CERTIFICATE OF ANALYSIS

Chain of Custody:	685108	Job Name:	Pointers Run Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	6600 South Trotter Road, Clarksville 21029	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/30/2026 - 10/01/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685108-1	: PRES-69 First-Draw	09/30/2026 5:58 AM	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.90 ug/L	
685108-2	: PRES-1 First-Draw	09/30/2026 6:00 AM	Commercial Sprayer, Cold, Yes (= Consumption), Kitchen, See Floor Plan, Sprayer, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	
685108-3	: PRES-2BW First-Draw	09/30/2026 5:55 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Fountain, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-4	: PRES-3 First-Draw	10/01/2026 6:10 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-5	: PRES-4 First-Draw	09/30/2026 5:52 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.7 ug/L	
685108-6	: PRES-5F First-Draw	09/30/2026 5:50 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	5.6 ug/L	This result meets or exceeds the 5.5ppb action level as established by MDE for schools.
685108-7	: PRES-9F First-Draw	09/30/2026 5:51 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.1 ug/L	
685108-8	: PRES-15F First-Draw	09/30/2026 5:48 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.5 ug/L	
685108-9	: PRES-16 First-Draw	09/30/2026 5:49 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-10	: PRES-29BW First-Draw	09/30/2026 5:46 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-11	: PRES-30 First-Draw	09/30/2026 6:02 AM	Drinking Water Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-12	: PRES-36F First-Draw	09/30/2026 5:45 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	4.0 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody:	685108	Job Name:	Pointers Run Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	6600 South Trotter Road, Clarksville 21029	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/30/2026 - 10/01/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685108-13	: PRES-37 First-Draw	09/30/2026 5:30 AM	Drinking Water Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-14	: PRES-48F First-Draw	09/30/2026 5:24 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.4 ug/L	
685108-15	: PRES-51F First-Draw	09/30/2026 5:25 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	6.0 ug/L	This result meets or exceeds the 5.5ppb action level as established by MDE for schools.
685108-16	: PRES-52 First-Draw	09/30/2026 5:21 AM	Drinking Water Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Hallway, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-17	: PRES-54F First-Draw	09/30/2026 5:22 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	3.2 ug/L	
685108-18	: PRES-55F First-Draw	09/30/2026 5:23 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.8 ug/L	
685108-19	: PRES-56F First-Draw	09/30/2026 5:26 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.4 ug/L	
685108-20	: PRES-65F First-Draw	09/30/2026 5:14 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.1 ug/L	
685108-21	: PRES-59F First-Draw	09/30/2026 5:09 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.2 ug/L	
685108-22	: PRES-60F First-Draw	09/30/2026 5:27 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	7.5 ug/L	This result meets or exceeds the 5.5ppb action level as established by MDE for schools.
685108-23	: PRES-62F First-Draw	09/30/2026 5:11 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.93 ug/L	
685108-24	: PRES-63F First-Draw	09/30/2026 5:12 AM	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubbler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody:	685108	Job Name:	Pointers Run Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	6600 South Trotter Road, Clarksville 21029	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/30/2026 - 10/01/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685108-25	: PRES-64F First-Draw	09/30/2026 5:13 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.91 ug/L	
685108-27	: PRES-66 First-Draw	09/30/2026 5:15 AM	Faucet, Cold, Yes (= Consumption), Nurse's Office/Health Room, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.66 ug/L	
685108-28	: PRES-67 First-Draw	09/30/2026 5:16 AM	Faucet, Cold, Yes (= Consumption), Office, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.66 ug/L	
685108-29	: PRES-68 First-Draw	09/30/2026 5:20 AM	Faucet, Cold, Yes (= Consumption), Staff Workroom, See Floor Plan, Sink, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	0.64 ug/L	
685108-30	: PRES-18F First-Draw	09/30/2026 5:42 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.3 ug/L	
685108-31	: PRES-22F First-Draw	09/30/2026 5:41 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	2.5 ug/L	
685108-32	: PRES-29BW First-Draw	10/01/2026 6:13 AM	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler, Yes (= Consumption), Hallway, See Floor Plan, Bottler Filler, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-33	: PRES-61F First-Draw	09/30/2026 5:10 AM	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated), Yes (= Consumption), Classroom, See Floor Plan, Bubblers, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	<0.5 ug/L	
685108-34	: PRES-1 Flush	09/30/2026 5:03 AM	Commercial Sprayer, Cold, Yes (= Consumption), Classroom, See Floor Plan, Sprayer, Main Bldg, 1st Floor					Void: Sample not analyzed, associated 1st draw <5.5ppb.

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)
Preparation Method: None
mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

Analyst(s): JP Littleton

Sample Collector: John Farmer
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.



CERTIFICATE OF ANALYSIS

Chain of Custody:	685108	Job Name:	Pointers Run Elementary School	Date Submitted:	10/02/2026
Client:	Howard County Public School System	Job Location:	6600 South Trotter Road, Clarksville 21029	Date Analyzed:	10/09/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	Job Number:	Not Provided	Report Date:	10/09/2026
Attention:	John Farmer	P.O. Number:	Not Provided	Date Sampled:	09/30/2026 - 10/01/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
-------------------	----------------------	-----------	----------	---------------	----------------	-----------------	--------------	----------

Technical
Director George Land

This report applies only to the sample(s) investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter, nor shall it be reproduced, except in full, without prior written authorization from us. Sample types, locations, collection protocols, air volumes and/or surface wipe area measurements are based upon information provided by the person(s) submitting them, and unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information and for analytical results calculated based on this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA LAP, NVLAP, NIST, or any agency of the Federal Government. All rights reserved. SGS AMA Analytical Services, Inc.