Maryland Water Quality Lab #262

NY ELAP Lab ID 10920

CERTIFICATE OF ANALYSIS

Chain of Custody:	685979	**Job Name:**	Long Reach High School	**Date Submitted:**	10/30/2026
Client:	Howard County Public School System	**Job Location:**	6101 Old Dobbin Lane, Columbia, MD 21045	**Date Analyzed:**	11/04/2026
Address:	10910 Clarksville Pike Ellicott City MD 21042	**Job Number:**	Not Provided	**Report Date:**	11/06/2026
Attention:	John Farmer	**P.O. Number:**	Not Provided	**Date Sampled:**	10/21/2026
				Person Submitting:	John Farmer

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Date/Time	Location	Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
685979-1	: LRHS-66 First Draw	10/21/2026 6:35 AM	Spigot (with threadings for hose connection), Yes (= Consumption), Outdoors, See Floor Plan, Hose Bib, Main Bldg, 1st Floor	ICP	Lead	0.5 ug/L	1.2 ug/L	

Analysis Method: ICP: EPA 200.8 (Rev. 5.4)
Preparation Method: None
mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

Sample Collector: John Farmer
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Analyst(s): JP Littleton



Technical Director George Land

This report applies only to the sample(s) investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter, nor shall it be reproduced, except in full, without prior written authorization from us. Sample types, locations, collection protocols, air volumes and/or surface wipe area measurements are based upon information provided by the person(s) submitting them, and unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information and for analytical results calculated based on this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. NVLAP accreditation applies only to polarized light microscopy of bulk samples and transmission electron microscopy of AHERA air samples. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA LAP, NVLAP, NIST, or any agency of the Federal Government. All rights reserved. SGS AMA Analytical Services, Inc.