



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Global Consulting, Inc.

Project Name: Altholton High School

Judi Darnell
6401 Golden Triangle Drive, Suite 304
Greenbelt, MD 20770

Project / PO Number: N/A
Received: 12/11/2018
Reported: 01/08/2019

Case Narrative

Microbac Laboratories, Inc. - Dayville

Revision 1 - 01/07/2019: Revised to report limit as 20 ppb.

Revision 2 - 01/08/2019: Revised to correct Baltimore's client sample ID's due log in error in Baltimore.

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (AHS-1, Drinking Water, 18L0812-01, etc.)

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result <1.0.

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (AHS-2, Drinking Water, 18L0812-02, etc.)

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 1.9.

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (AHS-3, Drinking Water, 18L0812-03, etc.)

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result <1.0.



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-4	Sample Matrix: Drinking Water	Collected By: Dhanika Ranasinghe, Madhusa
Lab Sample ID: 18L0812-04		Collection Date: 12/08/2018 5:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	1.3	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1440	DLO

Client Sample ID: AHS-5	Sample Matrix: Drinking Water	Collected By: Dhanika Ranasinghe, Madhusa
Lab Sample ID: 18L0812-05		Collection Date: 12/08/2018 5:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1442	DLO

Client Sample ID: AHS-6	Sample Matrix: Drinking Water	Collected By: Dhanika Ranasinghe, Madhusa
Lab Sample ID: 18L0812-06		Collection Date: 12/08/2018 5:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1444	DLO

Client Sample ID: AHS-7	Sample Matrix: Drinking Water	Collected By: Dhanika Ranasinghe, Madhusa
Lab Sample ID: 18L0812-07		Collection Date: 12/08/2018 5:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1450	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-8	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:19
Lab Sample ID: 18L0812-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1451	DLO

Client Sample ID: AHS-9	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:20
Lab Sample ID: 18L0812-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1453	DLO

Client Sample ID: AHS-10	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:22
Lab Sample ID: 18L0812-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1455	DLO

Client Sample ID: AHS-11	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:22
Lab Sample ID: 18L0812-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1457	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-12	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:28
Lab Sample ID: 18L0812-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1501	DLO

Client Sample ID: AHS-13	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:23
Lab Sample ID: 18L0812-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1503	DLO

Client Sample ID: AHS-14	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:24
Lab Sample ID: 18L0812-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1504	DLO

Client Sample ID: AHS-14A	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:27
Lab Sample ID: 18L0812-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1506	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-15	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:25
Lab Sample ID: 18L0812-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1512	DLO

Client Sample ID: AHS-16	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:25
Lab Sample ID: 18L0812-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1514	DLO

Client Sample ID: AHS-17	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:31
Lab Sample ID: 18L0812-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1516	DLO

Client Sample ID: AHS-18	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:32
Lab Sample ID: 18L0812-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1517	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-19	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:37
Lab Sample ID: 18L0812-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1406	12/27/18 1519	DLO

Client Sample ID: AHS-20	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:37
Lab Sample ID: 18L0812-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1529	DLO

Client Sample ID: AHS-21	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:38
Lab Sample ID: 18L0812-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1534	DLO

Client Sample ID: AHS-22	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:38
Lab Sample ID: 18L0812-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1536	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-23	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:39
Lab Sample ID: 18L0812-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	1.1	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1538	DLO

Client Sample ID: AHS-24	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:37
Lab Sample ID: 18L0812-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1540	DLO

Client Sample ID: AHS-25	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:40
Lab Sample ID: 18L0812-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1542	DLO

Client Sample ID: AHS-26	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:40
Lab Sample ID: 18L0812-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1547	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-27	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:36
Lab Sample ID: 18L0812-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1549	DLO

Client Sample ID: AHS-28	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:36
Lab Sample ID: 18L0812-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1551	DLO

Client Sample ID: AHS-29	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:32
Lab Sample ID: 18L0812-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1553	DLO

Client Sample ID: AHS-30	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:15
Lab Sample ID: 18L0812-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1555	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-31F	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 6:15
Lab Sample ID: 18L0812-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1558	DLO

Client Sample ID: AHS-31S	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:33
Lab Sample ID: 18L0812-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	1.7	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1600	DLO

Client Sample ID: AHS-32F	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 6:17
Lab Sample ID: 18L0812-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	1.1	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1602	DLO

Client Sample ID: AHS-32S	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:34
Lab Sample ID: 18L0812-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	1.3	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1604	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-33F	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 6:20
Lab Sample ID: 18L0812-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1610	DLO

Client Sample ID: AHS-33S	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:42
Lab Sample ID: 18L0812-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1611	DLO

Client Sample ID: AHS-34F	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 6:23
Lab Sample ID: 18L0812-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1613	DLO

Client Sample ID: AHS-34S	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:42
Lab Sample ID: 18L0812-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1615	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-35	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:54
Lab Sample ID: 18L0812-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1408	12/27/18 1617	DLO

Client Sample ID: AHS-36F	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 6:25
Lab Sample ID: 18L0812-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1626	DLO

Client Sample ID: AHS-36S	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:44
Lab Sample ID: 18L0812-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	2.6	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1632	DLO

Client Sample ID: AHS-37F	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 6:26
Lab Sample ID: 18L0812-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1634	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-37S	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:44
Lab Sample ID: 18L0812-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1636	DLO

Client Sample ID: AHS-38	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:45
Lab Sample ID: 18L0812-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1637	DLO

Client Sample ID: AHS-39	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:45
Lab Sample ID: 18L0812-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1639	DLO

Client Sample ID: AHS-40	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:47
Lab Sample ID: 18L0812-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1645	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-41	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:49
Lab Sample ID: 18L0812-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1647	DLO

Client Sample ID: AHS-42	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:50
Lab Sample ID: 18L0812-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1649	DLO

Client Sample ID: AHS-43	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:50
Lab Sample ID: 18L0812-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1650	DLO

Client Sample ID: AHS-44	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:51
Lab Sample ID: 18L0812-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1652	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-45	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:53
Lab Sample ID: 18L0812-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1656	DLO

Client Sample ID: AHS-46	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:53
Lab Sample ID: 18L0812-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1658	DLO

Client Sample ID: AHS-47	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:55
Lab Sample ID: 18L0812-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1700	DLO

Client Sample ID: AHS-48	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:55
Lab Sample ID: 18L0812-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1702	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-49	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:56
Lab Sample ID: 18L0812-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1707	DLO

Client Sample ID: AHS-50	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:57
Lab Sample ID: 18L0812-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1709	DLO

Client Sample ID: AHS-51	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:57
Lab Sample ID: 18L0812-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1711	DLO

Client Sample ID: AHS-52	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:58
Lab Sample ID: 18L0812-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1713	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-53	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:58
Lab Sample ID: 18L0812-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1409	12/27/18 1715	DLO

Client Sample ID: AHS-54	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 5:59
Lab Sample ID: 18L0812-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1724	DLO

Client Sample ID: AHS-55	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:00
Lab Sample ID: 18L0812-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1730	DLO

Client Sample ID: AHS-56F	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 7:10
Lab Sample ID: 18L0812-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1731	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-56S	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:01
Lab Sample ID: 18L0812-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1733	DLO

Client Sample ID: AHS-57	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:02
Lab Sample ID: 18L0812-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1735	DLO

Client Sample ID: AHS-58	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:01
Lab Sample ID: 18L0812-66	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<2.0	20.0 AL	2.0	ppb		12/27/18 1410	12/28/18 1031	DLO

Client Sample ID: AHS-59F	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/11/2018 7:12
Lab Sample ID: 18L0812-67	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1745	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-59S	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:03
Lab Sample ID: 18L0812-68	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1746	DLO

Client Sample ID: AHS-60	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:04
Lab Sample ID: 18L0812-69	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1748	DLO

Client Sample ID: AHS-61	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:05
Lab Sample ID: 18L0812-70	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1750	DLO

Client Sample ID: AHS-62	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:06
Lab Sample ID: 18L0812-71	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1752	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-63	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:10
Lab Sample ID: 18L0812-72	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1756	DLO

Client Sample ID: AHS-64	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:10
Lab Sample ID: 18L0812-73	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1758	DLO

Client Sample ID: AHS-65	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:12
Lab Sample ID: 18L0812-74	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1759	DLO

Client Sample ID: AHS-66	Collected By: Dhanika Ranasinghe, Madhusha
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:12
Lab Sample ID: 18L0812-75	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1805	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-67	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:12
Lab Sample ID: 18L0812-76	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1807	DLO

Client Sample ID: AHS-68	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:17
Lab Sample ID: 18L0812-77	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	2.8	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1809	DLO

Client Sample ID: AHS-69	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:13
Lab Sample ID: 18L0812-78	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1811	DLO

Client Sample ID: AHS-70	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:14
Lab Sample ID: 18L0812-79	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	2.6	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1812	DLO



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Client Sample ID: AHS-71	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:15
Lab Sample ID: 18L0812-80	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/27/18 1410	12/27/18 1814	DLO

Client Sample ID: AHS-72	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:13
Lab Sample ID: 18L0812-81	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/28/18 0942	12/28/18 1054	DLO

Client Sample ID: AHS-77	Collected By: Dhanika Ranasinghe, Madhusa
Sample Matrix: Drinking Water	Collection Date: 12/08/2018 6:18
Lab Sample ID: 18L0812-82	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<1.0	20.0 AL	1.0	ppb		12/28/18 0942	12/28/18 1116	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- RL: Reporting Limit

Project Requested Certification(s)

- Microbac Laboratories, Inc. - Baltimore E871126
- Microbac Laboratories, Inc. - Dayville 460279
- Florida - NELAC
- Department of General Services, VELAP



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0812

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "Jake Mason", is written over a light gray rectangular background.

Jake Mason

Client Relations

Reported: 01/08/2019 14:36