



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1527

KCI Technologies

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Atholton High

Project / PO Number: N/A
Received: 05/29/2019
Reported: 05/31/2019

Analytical Testing Parameters

Table with client sample details: Client Sample ID: AHS 73 First Draw DF/B, Sample Matrix: Drinking Water, Lab Sample ID: 19E1527-01, Collected By: Jeff Klenk, Collection Date: 05/21/2019 6:10

Table header for Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/30/19 1349, Analyzed 05/31/19 1215, Analyst GHW

Table with client sample details: Client Sample ID: AHS 74 First Draw OT.8, Sample Matrix: Drinking Water, Lab Sample ID: 19E1527-02, Collected By: Jeff Klenk, Collection Date: 05/21/2019 6:10

Table header for Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result 2.4, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/30/19 1412, Analyzed 05/31/19 1037, Analyst GHW

Table with client sample details: Client Sample ID: AHS 75 First Draw OT.3, Sample Matrix: Drinking Water, Lab Sample ID: 19E1527-03, Collected By: Jeff Klenk, Collection Date: 05/21/2019 6:10

Table header for Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/30/19 1349, Analyzed 05/31/19 1216, Analyst GHW

Table with client sample details: Client Sample ID: AHS 76 First Draw OT.3, Sample Matrix: Drinking Water, Lab Sample ID: 19E1527-04, Collected By: Jeff Klenk, Collection Date: 05/21/2019 6:10

Table header for Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result 52.0, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/30/19 1349, Analyzed 05/31/19 1217, Analyst GHW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1527

**Definitions**

RL: Reporting Limit

---

**Report Comments**

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

**Reviewed and Approved By:**

Evelyn Shinas  
Customer Relationship Coordinator  
Reported: 05/31/2019 15:16