



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

KCI Technologies

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Bushy Park Elementary School

Project / PO Number: N/A
Received: 03/19/2019
Reported: 03/28/2019

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (BPES 8 DF/C, Drinking Water, 19C1063-01, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (03/22/19 0944), Analyzed (03/22/19 1355), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (BPES 9 DF/C, Drinking Water, 19C1063-02, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (03/22/19 0944), Analyzed (03/22/19 1359), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (BPES 10 DF/C, Drinking Water, 19C1063-03, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (03/22/19 0944), Analyzed (03/22/19 1401), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (BPES 14 DF/C, Drinking Water, 19C1063-04, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (03/22/19 0944), Analyzed (03/22/19 1402), Analyst (GHW)



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 15 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1404	GHW

Client Sample ID: BPES 16F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1405	GHW

Client Sample ID: BPES 17F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1409	GHW

Client Sample ID: BPES 18F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1410	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 19F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1412	GHW

Client Sample ID: BPES 20F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1413	GHW

Client Sample ID: BPES 21F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1414	GHW

Client Sample ID: BPES 22F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1418	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 23F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1420	GHW

Client Sample ID: BPES 24 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1421	GHW

Client Sample ID: BPES 25F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1425	GHW

Client Sample ID: BPES 26 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1426	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 28F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1428	GHW

Client Sample ID: BPES 29F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1429	GHW

Client Sample ID: BPES 30F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1430	GHW

Client Sample ID: BPES 31F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1432	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 32F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1436	GHW

Client Sample ID: BPES 33F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1443	GHW

Client Sample ID: BPES 34F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		03/22/19 0944	03/22/19 1444	GHW

Client Sample ID: BPES 36F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1445	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 37 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1447	GHW

Client Sample ID: BPES 39 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		03/22/19 0944	03/22/19 1448	GHW

Client Sample ID: BPES 41F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1449	GHW

Client Sample ID: BPES 42F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1451	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 43F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1452	GHW

Client Sample ID: BPES 44F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1453	GHW

Client Sample ID: BPES 45F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1457	GHW

Client Sample ID: BPES 46F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1502	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 47F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1503	GHW

Client Sample ID: BPES 48F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1504	GHW

Client Sample ID: BPES 49F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1506	GHW

Client Sample ID: BPES 50F CC/B	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1507	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 60 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1508	GHW

Client Sample ID: BPES 65 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1510	GHW

Client Sample ID: BPES 73 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1514	GHW

Client Sample ID: BPES 75 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1515	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 85 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1519	GHW

Client Sample ID: BPES 86 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1538	GHW

Client Sample ID: BPES 90 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1539	GHW

Client Sample ID: BPES 91 DF/C	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/12/2019 5:00
Lab Sample ID: 19C1063-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1540	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 1 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1544	GHW

Client Sample ID: BPES 2 NO	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1546	GHW

Client Sample ID: BPES 3 TL	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		03/22/19 0944	03/22/19 1547	GHW

Client Sample ID: BPES 4 NO	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		03/22/19 0944	03/22/19 1549	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 7 TL	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		03/22/19 0944	03/22/19 1550	GHW

Client Sample ID: BPES 11 IM	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1551	GHW

Client Sample ID: BPES 12 KS	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.1	20.0	1.0	ppb		03/22/19 0944	03/22/19 1553	GHW

Client Sample ID: BPES 13 OT.7	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-52	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.3	20.0	1.0	ppb		03/22/19 0944	03/22/19 1557	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 16S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-53	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.6	20.0	1.0	ppb		03/22/19 0944	03/22/19 1601	GHW

Client Sample ID: BPES 17S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-54	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	4.5	20.0	1.0	ppb		03/22/19 0944	03/22/19 1602	GHW

Client Sample ID: BPES 18S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.8	20.0	1.0	ppb		03/22/19 0944	03/22/19 1604	GHW

Client Sample ID: BPES 19S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	4.7	20.0	1.0	ppb		03/22/19 0944	03/22/19 1605	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 20S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.1	20.0	1.0	ppb		03/22/19 0944	03/22/19 1606	GHW

Client Sample ID: BPES 21S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.8	20.0	1.0	ppb		03/22/19 0944	03/22/19 1608	GHW

Client Sample ID: BPES 22S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.5	20.0	1.0	ppb		03/22/19 0944	03/22/19 1609	GHW

Client Sample ID: BPES 23S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.0	20.0	1.0	ppb		03/22/19 0944	03/22/19 1611	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 25S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.9	20.0	1.0	ppb		03/22/19 1002	03/26/19 1625	GHW

Client Sample ID: BPES 27 TL	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-62	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		03/22/19 1002	03/26/19 1630	GHW

Client Sample ID: BPES 28S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-63	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.5	20.0	1.0	ppb		03/22/19 1002	03/26/19 1631	GHW

Client Sample ID: BPES 29S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-64	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.1	20.0	1.0	ppb		03/22/19 1002	03/26/19 1632	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 30S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-65	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		03/22/19 1002	03/26/19 1634	GHW

Client Sample ID: BPES 31S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-66	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.4	20.0	1.0	ppb		03/22/19 1002	03/26/19 1635	GHW

Client Sample ID: BPES 32S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-67	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	4.6	20.0	1.0	ppb		03/22/19 1002	03/26/19 1640	GHW

Client Sample ID: BPES 33S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-68	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		03/22/19 1002	03/26/19 1642	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 34S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-69	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1643	GHW

Client Sample ID: BPES 35 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-70	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.7	20.0	1.0	ppb		03/22/19 1002	03/26/19 1644	GHW

Client Sample ID: BPES 36S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-71	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.9	20.0	1.0	ppb		03/22/19 1002	03/26/19 1646	GHW

Client Sample ID: BPES 38 TL	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-72	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1650	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 41S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-73	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.5	20.0	1.0	ppb		03/22/19 1002	03/26/19 1651	GHW

Client Sample ID: BPES 42S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-74	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.6	20.0	1.0	ppb		03/22/19 1002	03/26/19 1653	GHW

Client Sample ID: BPES 43S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-75	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.1	20.0	1.0	ppb		03/22/19 1002	03/26/19 1658	GHW

Client Sample ID: BPES 44S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-76	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	7.9	20.0	1.0	ppb		03/22/19 1002	03/26/19 1659	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 45S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-77	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.4	20.0	1.0	ppb		03/22/19 1002	03/26/19 1701	GHW

Client Sample ID: BPES 46S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-78	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1702	GHW

Client Sample ID: BPES 47S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-79	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.1	20.0	1.0	ppb		03/22/19 1002	03/26/19 1703	GHW

Client Sample ID: BPES 48S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-80	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.4	20.0	1.0	ppb		03/22/19 1002	03/26/19 1705	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 49S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-81	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	4.1	20.0	1.0	ppb		03/22/19 1002	03/26/19 1709	GHW

Client Sample ID: BPES 50S CC/S	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-82	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	4.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1717	GHW

Client Sample ID: BPES 51 TL	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-83	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		03/22/19 1002	03/26/19 1718	GHW

Client Sample ID: BPES 54 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-84	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	74.1	20.0	1.0	ppb		03/22/19 1002	03/26/19 1720	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 55 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-85	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1721	GHW

Client Sample ID: BPES 56 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-86	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1723	GHW

Client Sample ID: BPES 57 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-87	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1724	GHW

Client Sample ID: BPES 58 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-88	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1725	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 59 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-89	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1727	GHW

Client Sample ID: BPES 61 TL	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-90	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1728	GHW

Client Sample ID: BPES 62 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-91	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1733	GHW

Client Sample ID: BPES 63 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-92	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1738	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 64 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-93	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		03/22/19 1002	03/26/19 1739	GHW

Client Sample ID: BPES 66 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-94	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		03/22/19 1002	03/26/19 1740	GHW

Client Sample ID: BPES 67 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-95	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1742	GHW

Client Sample ID: BPES 68 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-96	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1743	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 69 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-97	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1744	GHW

Client Sample ID: BPES 70 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-98	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		03/22/19 1002	03/26/19 1746	GHW

Client Sample ID: BPES 71 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-99	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1751	GHW

Client Sample ID: BPES 72 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1752	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 74 TL	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1756	GHW

Client Sample ID: BPES 76 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1800	GHW

Client Sample ID: BPES 77 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AD	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1802	GHW

Client Sample ID: BPES 78 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AE	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1803	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 79 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1808	GHW

Client Sample ID: BPES 80 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AG	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1810	GHW

Client Sample ID: BPES 81 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AH	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1811	GHW

Client Sample ID: BPES 82 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AI	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		03/22/19 1002	03/26/19 1812	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 83 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AJ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		03/22/19 1002	03/26/19 1814	GHW

Client Sample ID: BPES 84 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AK	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		03/22/19 1002	03/26/19 1815	GHW

Client Sample ID: BPES 87 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AL	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1816	GHW

Client Sample ID: BPES 88 OT.5	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AM	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	11.3	20.0	1.0	ppb		03/22/19 1002	03/26/19 1820	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 89 OT.5	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AN	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	66.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1825	GHW

Client Sample ID: BPES 92 CR	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AO	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		03/22/19 1002	03/26/19 1827	GHW

Client Sample ID: BPES 9BW OT.1	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AP	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1828	GHW

Client Sample ID: BPES 15BW OT.1	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AQ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1829	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Client Sample ID: BPES 65BW OT.1	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AR	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1831	GHW

Client Sample ID: BPES 75BW OT.1	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AS	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1832	GHW

Client Sample ID: BPES 85BW OT.1	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AT	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1833	GHW

Client Sample ID: BPES 90BW OT.1	Collected By: Jeffrey Klenk
Sample Matrix: Drinking Water	Collection Date: 03/13/2019 5:00
Lab Sample ID: 19C1063-AU	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		03/22/19 1002	03/26/19 1835	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19C1063

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "M Greenfield", written over a light gray rectangular background.

Megan Greenfield
Customer Relationship Coordinator
Reported: 03/28/2019 12:42