



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0843

KCI Technologies

Project Name: Bryant Woods Elementary School

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project / PO Number: N/A
Received: 05/13/2019
Reported: 05/16/2019

Analytical Testing Parameters

Table with 2 columns: Parameter and Value. Includes Client Sample ID (BWES 28 DF/C), Sample Matrix (Drinking Water), Lab Sample ID (19E0843-01), Collected By (Jeff Klenk), and Collection Date (04/30/2019 6:32).

Table with 9 columns: Metals, Total by EPA 200 Series Methods, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead shows result <1.0, limit 20.0, RL 1.0, units ppb, prepared 05/15/19 1655, analyzed 05/15/19 2008, analyst GHW.

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Megan Greenfield
Customer Relationship Coordinator
Reported: 05/16/2019 17:10