



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

KCI Technologies

Project Name: Cedar Lane School

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project / PO Number: N/A
Received: 12/03/2018
Reported: 01/02/2019

Analytical Testing Parameters

Table with sample details: Client Sample ID (CLS-01 OT - Administrative Workroom Sink OT), Sample Matrix (Drinking Water), Lab Sample ID (18L0312-01), Collected By (Rudy Scipio), Collection Date (12/01/2018 5:04)

Table header: Metals, Total by EPA 200 Series Methods. Columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row: Lead, Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 12/28/18 0724, Analyzed 12/28/18 1258, Analyst GHW

Table with sample details: Client Sample ID (CLS-02 TL - Teacher's Lounge Sink TL), Sample Matrix (Drinking Water), Lab Sample ID (18L0312-02), Collected By (Rudy Scipio), Collection Date (12/01/2018 5:05)

Table header: Metals, Total by EPA 200 Series Methods. Columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row: Lead, Result 4.0, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 12/28/18 0724, Analyzed 12/28/18 1302, Analyst GHW

Table with sample details: Client Sample ID (CLS-03 OT - Media Work Room OT), Sample Matrix (Drinking Water), Lab Sample ID (18L0312-03), Collected By (Rudy Scipio), Collection Date (12/01/2018 5:05)

Table header: Metals, Total by EPA 200 Series Methods. Columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row: Lead, Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 12/28/18 0724, Analyzed 12/28/18 1303, Analyst GHW

Table with sample details: Client Sample ID (CLS-04 TL - Teacher's Lounge Sink TL), Sample Matrix (Drinking Water), Lab Sample ID (18L0312-04), Collected By (Rudy Scipio), Collection Date (12/01/2018 5:07)

Table header: Metals, Total by EPA 200 Series Methods. Columns: Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst

Method: EPA 200.2/EPA 200.8

Table row: Lead, Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 12/28/18 0724, Analyzed 12/28/18 1305, Analyst GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-05 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:08
Lab Sample ID: 18L0312-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1306	GHW

Client Sample ID: CLS-06 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:09
Lab Sample ID: 18L0312-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1308	GHW

Client Sample ID: CLS-07 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:10
Lab Sample ID: 18L0312-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1313	GHW

Client Sample ID: CLS-08 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:11
Lab Sample ID: 18L0312-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1314	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-09 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:12
Lab Sample ID: 18L0312-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1315	GHW

Client Sample ID: CLS-10 TL - Teacher's Lounge Sink TL	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:14
Lab Sample ID: 18L0312-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1317	GHW

Client Sample ID: CLS-11 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:16
Lab Sample ID: 18L0312-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1318	GHW

Client Sample ID: CLS-12 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:17
Lab Sample ID: 18L0312-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1322	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-13 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:18
Lab Sample ID: 18L0312-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1324	GHW

Client Sample ID: CLS-14 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:18
Lab Sample ID: 18L0312-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1325	GHW

Client Sample ID: CLS-15 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:21
Lab Sample ID: 18L0312-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.7	20.0	1.0	ppb		12/28/18 0724	12/28/18 1330	GHW

Client Sample ID: CLS-16 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:22
Lab Sample ID: 18L0312-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1332	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-17 DF/C - Drinking Fountain/Chilled DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:24
Lab Sample ID: 18L0312-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1333	GHW

Client Sample ID: CLS-18 DF/C - Drinking Fountain/Chilled DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:24
Lab Sample ID: 18L0312-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1334	GHW

Client Sample ID: CLS-19 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:25
Lab Sample ID: 18L0312-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.6	20.0	1.0	ppb		12/28/18 0724	12/28/18 1336	GHW

Client Sample ID: CLS-20 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:25
Lab Sample ID: 18L0312-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		12/28/18 0724	12/28/18 1337	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-21 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:26
Lab Sample ID: 18L0312-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1341	GHW

Client Sample ID: CLS-22 DF/C - Drinking Fountain/Chilled DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:30
Lab Sample ID: 18L0312-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.1	20.0	1.0	ppb		12/28/18 0724	12/28/18 1349	GHW

Client Sample ID: CLS-23 DF/C - Drinking Fountain/Chilled DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:30
Lab Sample ID: 18L0312-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1350	GHW

Client Sample ID: CLS-24 KS - Kitchen Sink KS	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:32
Lab Sample ID: 18L0312-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		12/28/18 0724	12/28/18 1352	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-25 KS - Kitchen Sink KS	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:32
Lab Sample ID: 18L0312-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		12/28/18 0724	12/28/18 1353	GHW

Client Sample ID: CLS-26 KS - Kitchen Sink KS	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:35
Lab Sample ID: 18L0312-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1355	GHW

Client Sample ID: CLS-27 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:40
Lab Sample ID: 18L0312-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		12/28/18 0724	12/28/18 1356	GHW

Client Sample ID: CLS-28 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:41
Lab Sample ID: 18L0312-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1357	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-29 TL - Teacher's Lounge Sink TL	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:43
Lab Sample ID: 18L0312-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1359	GHW

Client Sample ID: CLS-30 DF/C - Drinking Fountain/Chilled DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:41
Lab Sample ID: 18L0312-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1400	GHW

Client Sample ID: CLS-31 DF/C - Drinking Fountain/Chilled DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:45
Lab Sample ID: 18L0312-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1405	GHW

Client Sample ID: CLS-32 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:47
Lab Sample ID: 18L0312-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1409	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-33 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:48
Lab Sample ID: 18L0312-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1411	GHW

Client Sample ID: CLS-34 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:49
Lab Sample ID: 18L0312-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1412	GHW

Client Sample ID: CLS-35 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:50
Lab Sample ID: 18L0312-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1414	GHW

Client Sample ID: CLS-36 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:51
Lab Sample ID: 18L0312-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1415	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-37 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:52
Lab Sample ID: 18L0312-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	12.2	20.0	1.0	ppb		12/28/18 0724	12/28/18 1416	GHW

Client Sample ID: CLS-39 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:06
Lab Sample ID: 18L0312-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1418	GHW

Client Sample ID: CLS-40 DF/C - Drinking Fountain/Chilled DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:08
Lab Sample ID: 18L0312-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1423	GHW

Client Sample ID: CLS-41 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:10
Lab Sample ID: 18L0312-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1424	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-42 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:10
Lab Sample ID: 18L0312-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1428	GHW

Client Sample ID: CLS-43 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:12
Lab Sample ID: 18L0312-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1433	GHW

Client Sample ID: CLS-44 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:12
Lab Sample ID: 18L0312-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1434	GHW

Client Sample ID: CLS-45 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:14
Lab Sample ID: 18L0312-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1435	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-46 TL - Teacher's Lounge Sink TL	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:15
Lab Sample ID: 18L0312-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	7.7	20.0	1.0	ppb		12/13/18 1724	12/14/18 1620	GHW

Client Sample ID: CLS-47 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:19
Lab Sample ID: 18L0312-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1441	GHW

Client Sample ID: CLS-48 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:20
Lab Sample ID: 18L0312-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.2	20.0	1.0	ppb		12/28/18 0724	12/28/18 1442	GHW

Client Sample ID: CLS-49 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:22
Lab Sample ID: 18L0312-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1443	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-50 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:24
Lab Sample ID: 18L0312-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1445	GHW

Client Sample ID: CLS-51 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:28
Lab Sample ID: 18L0312-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		12/28/18 0724	12/28/18 1446	GHW

Client Sample ID: CLS-52 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:29
Lab Sample ID: 18L0312-52	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1447	GHW

Client Sample ID: CLS-53 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:30
Lab Sample ID: 18L0312-53	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		12/28/18 0724	12/28/18 1449	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-54 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:30
Lab Sample ID: 18L0312-54	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1453	GHW

Client Sample ID: CLS-55 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:32
Lab Sample ID: 18L0312-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.2	20.0	1.0	ppb		12/28/18 0724	12/28/18 1458	GHW

Client Sample ID: CLS-56 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:33
Lab Sample ID: 18L0312-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1500	GHW

Client Sample ID: CLS-57 TL - Teacher's Lounge Sink TL	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:35
Lab Sample ID: 18L0312-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1501	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-58 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:37
Lab Sample ID: 18L0312-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	10.9	20.0	1.0	ppb		12/28/18 0724	12/28/18 1502	GHW

Client Sample ID: CLS-59 CR - Classroom Sink CR	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:40
Lab Sample ID: 18L0312-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1504	GHW

Client Sample ID: CLS-60 TL - Teacher's Lounge Sink TL	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:48
Lab Sample ID: 18L0312-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1505	GHW

Client Sample ID: CLS-61 TL - Teacher's Lounge Sink TL	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:47
Lab Sample ID: 18L0312-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.4	20.0	1.0	ppb		12/28/18 0724	12/28/18 1507	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-62 NO - Nurse's Office Sink NO	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:48
Lab Sample ID: 18L0312-62	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/28/18 0724	12/28/18 1508	GHW

Client Sample ID: CLS-63 NO - Nurse's Office Sink NO	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:48
Lab Sample ID: 18L0312-63	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/14/18 1139	12/21/18 1900	LMH

Client Sample ID: CLS-64 NO - Nurse's Office Sink NO	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:49
Lab Sample ID: 18L0312-64	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/14/18 1139	12/21/18 1901	LMH

Client Sample ID: CLS-65 NO - Nurse's Office Sink NO	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 6:50
Lab Sample ID: 18L0312-65	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		12/14/18 1139	12/21/18 1902	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0312

Client Sample ID: CLS-66 Café DF/C DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:35
Lab Sample ID: 18L0312-66	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/14/18 1139	12/21/18 1903	LMH

Client Sample ID: CLS-67 Café DF/C DF	Collected By: Rudy Scipio
Sample Matrix: Drinking Water	Collection Date: 12/01/2018 5:35
Lab Sample ID: 18L0312-67	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		12/14/18 1139	12/21/18 1905	LMH

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions
 RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Jake Mason
 Client Relations
 Reported: 01/02/2019 10:28