



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

KCI Technologies

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Gorman Crossing Elementary

School
Project / PO Number: N/A
Received: 05/13/2019
Reported: 05/22/2019

Analytical Testing Parameters

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 6 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1517	GHW

Client Sample ID: GCES 7F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1518	GHW

Client Sample ID: GCES 8F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1522	GHW

Client Sample ID: GCES 9F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1524	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 11F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1525	GHW

Client Sample ID: GCES 12F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1526	GHW

Client Sample ID: GCES 13 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1528	GHW

Client Sample ID: GCES 14F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1532	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 16F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1533	GHW

Client Sample ID: GCES 17F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1534	GHW

Client Sample ID: GCES 19F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1538	GHW

Client Sample ID: GCES 20F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1540	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 21F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1541	GHW

Client Sample ID: GCES 22F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1542	GHW

Client Sample ID: GCES 23F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1544	GHW

Client Sample ID: GCES 25F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1545	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 26F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1549	GHW

Client Sample ID: GCES 27F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1556	GHW

Client Sample ID: GCES 28F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1557	GHW

Client Sample ID: GCES 29 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1558	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 30F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1600	GHW

Client Sample ID: GCES 31F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.6	20.0	1.0	ppb		05/21/19 1513	05/22/19 1052	GHW

Client Sample ID: GCES 32F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1601	GHW

Client Sample ID: GCES 33F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1602	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 34F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1604	GHW

Client Sample ID: GCES 35F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1605	GHW

Client Sample ID: GCES 36 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1606	GHW

Client Sample ID: GCES 37F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1610	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 38F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1614	GHW

Client Sample ID: GCES 39F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1616	GHW

Client Sample ID: GCES 40F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1617	GHW

Client Sample ID: GCES 42F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1618	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 43F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1620	GHW

Client Sample ID: GCES 44F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1621	GHW

Client Sample ID: GCES 45 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1622	GHW

Client Sample ID: GCES 46F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1626	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 47F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1628	GHW

Client Sample ID: GCES 48F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1632	GHW

Client Sample ID: GCES 50F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1636	GHW

Client Sample ID: GCES 51F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1637	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 52 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1639	GHW

Client Sample ID: GCES 53F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1642	GHW

Client Sample ID: GCES 54F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1644	GHW

Client Sample ID: GCES 58F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1645	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 59F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1647	GHW

Client Sample ID: GCES 60F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1648	GHW

Client Sample ID: GCES 61F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1649	GHW

Client Sample ID: GCES 62F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-52	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1651	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 63F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-53	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1655	GHW

Client Sample ID: GCES 64F DF/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/09/2019 5:15
Lab Sample ID: 19E0846-54	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1659	GHW

Client Sample ID: GCES 1 KS	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		05/17/19 1010	05/17/19 1700	GHW

Client Sample ID: GCES 3S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1701	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 7S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1703	GHW

Client Sample ID: GCES 8S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1704	GHW

Client Sample ID: GCES 9S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1705	GHW

Client Sample ID: GCES 10 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1010	05/17/19 1707	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 11S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1642	GHW

Client Sample ID: GCES 12S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-62	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1649	GHW

Client Sample ID: GCES 14S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-63	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1651	GHW

Client Sample ID: GCES 15 OT.7	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-64	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1653	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 16S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-65	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1655	GHW

Client Sample ID: GCES 17S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-66	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1658	GHW

Client Sample ID: GCES 18 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-67	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1704	GHW

Client Sample ID: GCES 19S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-68	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1706	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 20S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-69	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1708	GHW

Client Sample ID: GCES 21S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-70	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1711	GHW

Client Sample ID: GCES 22S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-71	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1713	GHW

Client Sample ID: GCES 23S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-72	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1719	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 24 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-73	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1722	GHW

Client Sample ID: GCES 25S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-74	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1724	GHW

Client Sample ID: GCES 26S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-75	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1730	GHW

Client Sample ID: GCES 27S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-76	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1732	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 28S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-77	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1735	GHW

Client Sample ID: GCES 30S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-78	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1737	GHW

Client Sample ID: GCES 31S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-79	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1739	GHW

Client Sample ID: GCES 32S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-80	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1741	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 33S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-81	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1748	GHW

Client Sample ID: GCES 34S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-82	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1759	GHW

Client Sample ID: GCES 35S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-83	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1801	GHW

Client Sample ID: GCES 37S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-84	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1803	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 38S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-85	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1805	GHW

Client Sample ID: GCES 39S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-86	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1807	GHW

Client Sample ID: GCES 40S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-87	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1810	GHW

Client Sample ID: GCES 41 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-88	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1812	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 42S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-89	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1814	GHW

Client Sample ID: GCES 43S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-90	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1816	GHW

Client Sample ID: GCES 44S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-91	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1823	GHW

Client Sample ID: GCES 46S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-92	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1829	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 47S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-93	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1832	GHW

Client Sample ID: GCES 48S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-94	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1834	GHW

Client Sample ID: GCES 49 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-95	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1836	GHW

Client Sample ID: GCES 50S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-96	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1838	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 51S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-97	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1840	GHW

Client Sample ID: GCES 53S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-98	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1843	GHW

Client Sample ID: GCES 54S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-99	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1849	GHW

Client Sample ID: GCES 55 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1851	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 56 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1858	GHW

Client Sample ID: GCES 57 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1904	GHW

Client Sample ID: GCES 58S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AD	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1906	GHW

Client Sample ID: GCES 59S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AE	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1908	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID: GCES 60S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1915	GHW

Client Sample ID: GCES 61S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AG	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1917	GHW

Client Sample ID: GCES 62S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AH	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1919	GHW

Client Sample ID: GCES 63S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/10/2019 5:15
Lab Sample ID: 19E0846-AI	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1921	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0846

Client Sample ID:	GCES 64S NO	Collected By:	Jeff Klenk
Sample Matrix:	Drinking Water	Collection Date:	05/10/2019 5:15
Lab Sample ID:	19E0846-AJ		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1923	GHW

Client Sample ID:	GCES 65 OT.2	Collected By:	Jeff Klenk
Sample Matrix:	Drinking Water	Collection Date:	05/10/2019 5:15
Lab Sample ID:	19E0846-AK		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1926	GHW

Client Sample ID:	GCES 66 TL	Collected By:	Jeff Klenk
Sample Matrix:	Drinking Water	Collection Date:	05/10/2019 5:15
Lab Sample ID:	19E0846-AL		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1057	05/20/19 1928	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:



Megan Greenfield
Customer Relationship Coordinator
Reported: 05/22/2019 16:15