



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0845

KCI Technologies

Project Name: Glenelg High School

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project / PO Number: N/A
Received: 05/13/2019
Reported: 05/16/2019

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (GHS 18A OT.3, Drinking Water, 19E0845-01, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (9.3), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (05/15/19 1655), Analyzed (05/15/19 2018), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (GHS 56 OT.6, Drinking Water, 19E0845-02, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (23.8), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (05/15/19 1655), Analyzed (05/15/19 2019), Analyst (GHW)

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Handwritten signature of Megan Greenfield

Megan Greenfield
Customer Relationship Coordinator
Reported: 05/16/2019 17:08

Microbac Laboratories, Inc.

2101 Van Deman Street | Baltimore, MD 21224 | 410.633.1800 p | www.microbac.com