



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Revised Report: Workorder modified- See Case Narrative.

Global Consulting, Inc.

Project Name: Hammond High School

Judi Darnell
6401 Golden Triangle Drive, Suite 304
Greenbelt, MD 20770

Project / PO Number: N/A
Received: 10/31/2018
Reported: 10/16/2019

Case Narrative

MMM 10/16/2019 Work order amended to change Report Limit per client request. See email attached.

Analytical Testing Parameters

Table with 2 columns: Parameter and Value. Includes Client Sample ID (HAHS-1), Sample Matrix (Drinking Water), Lab Sample ID (18J1604-01), Collected By (Customer), and Collection Date (10/27/2018 5:30).

Table with 10 columns: Metals, Total by EPA 200 Series Methods, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: Result <1.0, Limit 20.0, RL 1.0, Units ppb, Prepared 11/05/18 1112, Analyzed 11/05/18 1335, Analyst LMH.

Table with 2 columns: Parameter and Value. Includes Client Sample ID (HAHS-2), Sample Matrix (Drinking Water), Lab Sample ID (18J1604-02), Collected By (Customer), and Collection Date (10/27/2018 5:34).

Table with 10 columns: Metals, Total by EPA 200 Series Methods, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: Result 1.6, Limit 20.0, RL 1.0, Units ppb, Prepared 11/05/18 1112, Analyzed 11/05/18 1338, Analyst LMH.

Table with 2 columns: Parameter and Value. Includes Client Sample ID (HAHS-3), Sample Matrix (Drinking Water), Lab Sample ID (18J1604-03), Collected By (Customer), and Collection Date (10/27/2018 5:36).

Table with 10 columns: Metals, Total by EPA 200 Series Methods, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: Result 8.4, Limit 20.0, RL 1.0, Units ppb, Prepared 11/05/18 1112, Analyzed 11/05/18 1500, Analyst LMH.



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-4	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-04		Collection Date: 10/27/2018 5:39

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1339	LMH

Client Sample ID: HAHS-5	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-05		Collection Date: 10/27/2018 5:45

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1340	LMH

Client Sample ID: HAHS-6	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-06		Collection Date: 10/27/2018 5:51

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1341	LMH

Client Sample ID: HAHS-7	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-07		Collection Date: 10/27/2018 6:00

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		11/05/18 1112	11/05/18 1342	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-8	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-08		Collection Date: 10/27/2018 6:07

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		11/05/18 1112	11/05/18 1346	LMH

Client Sample ID: HAHS-9	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-09		Collection Date: 10/27/2018 6:12

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1347	LMH

Client Sample ID: HAHS-10	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-10		Collection Date: 10/27/2018 6:18

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1348	LMH

Client Sample ID: HAHS-11	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-11		Collection Date: 10/27/2018 6:22

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	75.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1349	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-12	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 6:25
Lab Sample ID: 18J1604-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		11/05/18 1112	11/05/18 1351	LMH

Client Sample ID: HAHS-13	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 6:27
Lab Sample ID: 18J1604-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1354	LMH

Client Sample ID: HAHS-13A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 6:31
Lab Sample ID: 18J1604-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	8.9	20.0	1.0	ppb		11/05/18 1112	11/05/18 1355	LMH

Client Sample ID: HAHS-14	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 6:34
Lab Sample ID: 18J1604-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1356	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-15	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-16		Collection Date: 10/27/2018 6:38

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1400	LMH

Client Sample ID: HAHS-16	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-17		Collection Date: 10/27/2018 6:44

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		11/05/18 1112	11/05/18 1401	LMH

Client Sample ID: HAHS-16BW	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-18		Collection Date: 10/31/2018 6:20

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		11/05/18 1112	11/05/18 1402	LMH

Client Sample ID: HAHS-17	Sample Matrix: Drinking Water	Collected By: Customer
Lab Sample ID: 18J1604-19		Collection Date: 10/27/2018 6:47

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.3	20.0	1.0	ppb		11/05/18 1112	11/05/18 1403	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-18	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 6:50
Lab Sample ID: 18J1604-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1422	11/06/18 1038	LMH

Client Sample ID: HAHS-18A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 6:54
Lab Sample ID: 18J1604-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1404	LMH

Client Sample ID: HAHS-19	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:01
Lab Sample ID: 18J1604-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.8	20.0	1.0	ppb		11/05/18 1112	11/05/18 1405	LMH

Client Sample ID: HAHS-20	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:05
Lab Sample ID: 18J1604-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		11/05/18 1112	11/05/18 1408	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-21	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:09
Lab Sample ID: 18J1604-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1414	LMH

Client Sample ID: HAHS-22	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:14
Lab Sample ID: 18J1604-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	7.2	20.0	1.0	ppb		11/05/18 1112	11/05/18 1415	LMH

Client Sample ID: HAHS-23	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:18
Lab Sample ID: 18J1604-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		11/05/18 1112	11/05/18 1417	LMH

Client Sample ID: HAHS-24	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:22
Lab Sample ID: 18J1604-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	10.9	20.0	1.0	ppb		11/05/18 1112	11/05/18 1418	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-25	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:25
Lab Sample ID: 18J1604-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	14.6	20.0	1.0	ppb		11/05/18 1112	11/05/18 1419	LMH

Client Sample ID: HAHS-26	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:30
Lab Sample ID: 18J1604-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1420	LMH

Client Sample ID: HAHS-27	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:35
Lab Sample ID: 18J1604-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		11/05/18 1112	11/05/18 1421	LMH

Client Sample ID: HAHS-28	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:41
Lab Sample ID: 18J1604-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		11/05/18 1112	11/05/18 1422	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-29	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:50
Lab Sample ID: 18J1604-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1423	LMH

Client Sample ID: HAHS-30	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:53
Lab Sample ID: 18J1604-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.8	20.0	1.0	ppb		11/05/18 1112	11/05/18 1427	LMH

Client Sample ID: HAHS-31	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 7:59
Lab Sample ID: 18J1604-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	6.6	20.0	1.0	ppb		11/05/18 1112	11/05/18 1430	LMH

Client Sample ID: HAHS-32	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:07
Lab Sample ID: 18J1604-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	8.9	20.0	1.0	ppb		11/05/18 1112	11/05/18 1431	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-33	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:09
Lab Sample ID: 18J1604-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	6.5	20.0	1.0	ppb		11/05/18 1112	11/05/18 1432	LMH

Client Sample ID: HAHS-34	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:12
Lab Sample ID: 18J1604-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.8	20.0	1.0	ppb		11/05/18 1112	11/05/18 1433	LMH

Client Sample ID: HAHS-35	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:14
Lab Sample ID: 18J1604-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	22.8	20.0	1.0	ppb		11/05/18 1112	11/05/18 1434	LMH

Client Sample ID: HAHS-36	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:16
Lab Sample ID: 18J1604-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1435	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-37	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:18
Lab Sample ID: 18J1604-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.6	20.0	1.0	ppb		11/05/18 1112	11/05/18 1436	LMH

Client Sample ID: HAHS-38	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:21
Lab Sample ID: 18J1604-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.3	20.0	1.0	ppb		11/05/18 1112	11/05/18 1441	LMH

Client Sample ID: HAHS-39	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:23
Lab Sample ID: 18J1604-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.2	20.0	1.0	ppb		11/05/18 1112	11/05/18 1442	LMH

Client Sample ID: HAHS-40	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:29
Lab Sample ID: 18J1604-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	6.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1445	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-41	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:32
Lab Sample ID: 18J1604-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		11/05/18 1112	11/05/18 1448	LMH

Client Sample ID: HAHS-42	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:40
Lab Sample ID: 18J1604-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	17.4	20.0	1.0	ppb		11/05/18 1112	11/05/18 1449	LMH

Client Sample ID: HAHS-43	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:45
Lab Sample ID: 18J1604-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1450	LMH

Client Sample ID: HAHS-44	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 8:50
Lab Sample ID: 18J1604-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.6	20.0	1.0	ppb		11/05/18 1112	11/05/18 1454	LMH



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18J1604

Client Sample ID: HAHS-45	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/27/2018 9:03
Lab Sample ID: 18J1604-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		11/05/18 1112	11/05/18 1455	LMH

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Baltimore
E871126

Florida - NELAC

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Marissa Mamone
Client Relations

Reported: 10/16/2019 15:21