



# EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077  
Tel/Fax: (800) 220-3675 / (856) 786-0262  
<http://www.EMSL.com / cinnmicrolab@emsl.com>

EMSL Order: 371924390

Customer ID: WATE78

Customer PO:

Project ID:

**Attention:** Eric Messerschmidt  
WaterPro, Inc.  
5690 French Avenue  
Sykesville, MD 21784

**Phone:** (410) 746-1111

**Fax:** (410) 551-6053

**Collected Date:** 10/28/2019 07:15 AM - 10/28/2019 12:00 PM

**Received Date:** 10/29/2019 10:10 AM

**Processed Date:** 10/29/2019 03:15 PM

**Analyzed Date:** 11/06/2019 08:00 AM

**Project:** HCPSS - Retest #2

## Legionella Detection - Presumptive ID by CDC Culture Method (EMSL Method M210)

Client Sample ID/Sample Location Lab Sample Number	Sample Type	Volume Submitted (mL)	Volume Filtered (mL)	Method Processed	Identification	Volume Examined (mL)	Limit of Detection (CFU/mL)	Final Results (CFU/mL)
1 - Marriotts Ridge HS 371924390-0001	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
2 - Hammond HS 371924390-0002	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
3 - Mt. Hebron HS 371924390-0003	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
4 - Laurel Woods ES 371924390-0004	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
5 - West Friendship ES 371924390-0005	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
6 - Long Reach HS 371924390-0006	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
7 - River Hill 371924390-0007	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
8 - Atholton HS 371924390-0008	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
9 - Howard HS Tower 1 371924390-0009	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
10 - Howard HS Tower 2 371924390-0010	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND
11 - Howard HS Tower 3 371924390-0011	Non-potable	100	NA	Direct Plate	None Detected	0.1	10.00	ND

Vincent Iuzzolino, M.S., Laboratory Director  
or other Approved Signatory

Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. The report reflects the samples as received. When the information supplied by the customer can affect the validity of the result, it will be noted on the report.

AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Report Amended: 11/12/2019 02:56 PM Replaces initial report from: 11/07/2019 02:28 PM Reason Code Client-Change to Location

Printed 11/12/2019 02:57 PM

Page 1 of 1

MIC\_CDCISO\_0017