



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-1	HHES 3 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-2	HHES 4 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-3	HHES 5 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-4	HHES 6F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-5	HHES 7F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-6	HHES 8F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-7	HHES 9F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-8	HHES 10F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-9	HHES 11F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	0.55 ug/L	
620180-10	HHES 12F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-11	HHES 13F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-12	HHES 14F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-13	HHES 15F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-14	HHES 16 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-15	HHES 17F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-16	HHES 18F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	0.96 ug/L	
620180-17	HHES 19F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-18	HHES 20F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-19	HHES 21F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-20	HHES 22F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-21	HHES 23F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-22	HHES 24F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-23	HHES 25F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-24	HHES 26 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-25	HHES 27F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-26	HHES 28F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-27	HHES 29F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-28	HHES 30F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-29	HHES 31F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-30	HHES 32F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	0.53 ug/L	
620180-31	HHES 33F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-32	HHES 34F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-33	HHES 35F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-34	HHES 36F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-35	HHES 37 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-36	HHES 38 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-37	HHES 41F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-38	HHES 45F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-39	HHES 46 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-40	HHES 47 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-41	HHES 49F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-42	HHES 50F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	0.54 ug/L	
620180-43	HHES 51F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	0.52 ug/L	
620180-44	HHES 52F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	0.51 ug/L	
620180-45	HHES 53F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-46	HHES 54F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-47	HHES 55 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-48	HHES 56F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-49	HHES 57F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-50	HHES 58F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-51	HHES 59F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-52	HHES 60F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-53	HHES 61F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-54	HHES 62F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-55	HHES 63F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-56	HHES 64F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-57	HHES 65F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	0.91 ug/L	
620180-58	HHES 66F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-59	HHES 67 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-60	HHES 68F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-61	HHES 69F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-62	HHES 70F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-63	HHES 71F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-64	HHES 72F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-65	HHES 73F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-66	HHES 74F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-67	HHES 75F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-68	HHES 76F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-69	HHES 77F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-70	HHES 78 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-71	HHES 79 FD	01/16/2020 5:15 am	DF/C	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-72	HHES 80F FD	01/16/2020 5:15 am	CC/B	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-73	HHES 1 FD	01/17/2020 5:33 am	IM	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-74	HHES 2 FD	01/17/2020 5:33 am	KS	ICP	Lead	0.5 ug/L	1.2 ug/L	
620180-75	HHES 3BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-76	HHES 4BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-77	HHES 6S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-78	HHES 7S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-79	HHES 8S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-80	HHES 9S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-81	HHES 10S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-82	HHES 11S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-83	HHES 12S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-84	HHES 13S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-85	HHES 14S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-86	HHES 15S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-87	HHES 16BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-88	HHES 17S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.55 ug/L	
620180-89	HHES 18S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.57 ug/L	
620180-90	HHES 19S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-91	HHES 20S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-92	HHES 21S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.72 ug/L	
620180-93	HHES 22S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.65 ug/L	
620180-94	HHES 23S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-95	HHES 24S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-96	HHES 25S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-97	HHES 26BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-98	HHES 27S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-99	HHES 28S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-100	HHES 29S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180

Job Name: Hanover Hills Elementary School

Date Submitted: 01/24/2020

Client: Howard County Public School System

Job Location: 7030 Banbury Drive, Elkridge MD
21076

Date Analyzed: 01/30/2020

Address: 10910 Route 108
Ellicott City, MD 21042

Job Number: 13.999

Report Date: 01/31/2020

Attention: Jeff Klenk

P.O. Number: Not Provided

Date Sampled: 01/16/2020

Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-101	HHES 30S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.64 ug/L	
620180-102	HHES 31S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-103	HHES 32S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-104	HHES 33S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-105	HHES 34S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-106	HHES 35S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-107	HHES 36S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-108	HHES 37BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-109	HHES 39 FD	01/17/2020 5:33 am	TL	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-110	HHES 40 FD	01/17/2020 5:33 am	OT.7	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-111	HHES 41S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-112	HHES 42 FD	01/17/2020 5:33 am	NO	ICP	Lead	0.5 ug/L	0.58 ug/L	
620180-113	HHES 43 FD	01/17/2020 5:33 am	OT.2	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-114	HHES 44 FD	01/17/2020 5:33 am	CR	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-115	HHES 45S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.57 ug/L	
620180-116	HHES 47BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-117	HHES 48 FD	01/17/2020 5:33 am	TL	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-118	HHES 49S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.75 ug/L	
620180-119	HHES 50S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.71 ug/L	
620180-120	HHES 51S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.76 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-121	HHES 52S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-122	HHES 53S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-123	HHES 54S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-124	HHES 55BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-125	HHES 56S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-126	HHES 57S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-127	HHES 58S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-128	HHES 59S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-129	HHES 60S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-130	HHES 61S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-131	HHES 62S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-132	HHES 63S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-133	HHES 64S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-134	HHES 65S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.82 ug/L	
620180-135	HHES 66S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-136	HHES 67BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-137	HHES 68S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	1.2 ug/L	
620180-138	HHES 69S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-139	HHES 70S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-140	HHES 71S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
 Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
 21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					
620180-141	HHES 72S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-142	HHES 73S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-143	HHES 74S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-144	HHES 75S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.53 ug/L	
620180-145	HHES 76S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-146	HHES 77S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.51 ug/L	
620180-147	HHES 79BW FD	01/17/2020 5:33 am	OT.1	ICP	Lead	0.5 ug/L	< 0.5 ug/L	
620180-148	HHES 80S FD	01/17/2020 5:33 am	CC/S	ICP	Lead	0.5 ug/L	0.69 ug/L	
620180-149	HHES 81 FD	01/17/2020 5:33 am	OT.5	ICP	Lead	0.5 ug/L	0.56 ug/L	
620180-150	HHES 82 FD	01/17/2020 5:33 am	OT.5	ICP	Lead	0.5 ug/L	0.61 ug/L	



CERTIFICATE OF ANALYSIS

Chain of Custody: 620180
Client: Howard County Public School System
Address: 10910 Route 108
 Ellicott City, MD 21042
Attention: Jeff Klenk

Job Name: Hanover Hills Elementary School
Job Location: 7030 Banbury Drive, Elkridge MD
 21076
Job Number: 13.999
P.O. Number: Not Provided

Date Submitted: 01/24/2020
Date Analyzed: 01/30/2020
Report Date: 01/31/2020
Date Sampled: 01/16/2020
Person Submitting: Jeff Klenk

Summary of Drinking Water Analysis for Metals

AMA Sample Number	Client Sample Number	Sample Collection Information		Analysis Type	Sample Analyte	Reporting Limit	Final Result	Comments
		Date/Time	Location					

Analysis Methods: Flame AA: APHA SM3111B (1999, 22nd Ed.), Furnace AA: APHA SM3113B (2010, 22nd Ed.), ICP: EPA 200.8 (Rev. 5.4)

mg/L = Parts Per Million (ppm), N/A = Not Applicable, µg/L = Parts Per Billion, N/P = Not Provided

Analyst(s): Jean-Paul Littleton, Suphin Chinnapad

Sample Collector: Jeff Klenk
Certification:

All results are to be considered preliminary and subject to change unless signed by the Technical Director or Deputy.

Technical Director Jean-Paul Littleton

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from us. Sample types, locations, and collection protocols are based upon the information provided by the persons submitting them and, unless collected by personnel of these Laboratories, we expressly disclaim any knowledge and liability for the accuracy and completeness of this information. Residual sample material will be discarded in accordance with the appropriate regulatory guidelines, unless otherwise requested by the client. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NY ELAP, AIHA-LAP, or any agency of the Federal Government. All rights reserved. AMA Analytical Services, Inc.