



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

KCI Technologies

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Hanover Hills ES

Project / PO Number: N/A
Received: 04/01/2019
Reported: 04/08/2019

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (HHES 3 DF/C C, Drinking Water, 19D0396-01, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (04/04/19 1318), Analyzed (04/04/19 1823), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (HHES 4 DF/C C, Drinking Water, 19D0396-02, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (04/04/19 1318), Analyzed (04/04/19 1824), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (HHES 5 DF/C C, Drinking Water, 19D0396-03, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (04/04/19 1318), Analyzed (04/04/19 1826), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (HHES 6F CC/B C, Drinking Water, 19D0396-04, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (04/04/19 1318), Analyzed (04/04/19 1831), Analyst (GHW)



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 7F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1832	GHW

<b>Client Sample ID:</b> HHES 8F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1836	GHW

<b>Client Sample ID:</b> HHES 9F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1840	GHW

<b>Client Sample ID:</b> HHES 10F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1842	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 11F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1843	GHW

<b>Client Sample ID:</b> HHES 12F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1848	GHW

<b>Client Sample ID:</b> HHES 13F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1850	GHW

<b>Client Sample ID:</b> HHES 14F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1851	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 15F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1852	GHW

<b>Client Sample ID:</b> HHES 16 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1854	GHW

<b>Client Sample ID:</b> HHES 17F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1855	GHW

<b>Client Sample ID:</b> HHES 18F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.4	20.0	1.0	ppb		04/04/19 1318	04/04/19 1856	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 19F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1900	GHW

<b>Client Sample ID:</b> HHES 20F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1906	GHW

<b>Client Sample ID:</b> HHES 21F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1907	GHW

<b>Client Sample ID:</b> HHES 22F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1908	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 23F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1910	GHW

<b>Client Sample ID:</b> HHES 24F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1911	GHW

<b>Client Sample ID:</b> HHES 25F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1912	GHW

<b>Client Sample ID:</b> HHES 26 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1914	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 27F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1318	04/04/19 1915	GHW

<b>Client Sample ID:</b> HHES 28F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1117	GHW

<b>Client Sample ID:</b> HHES 29F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1121	GHW

<b>Client Sample ID:</b> HHES 30F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1122	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 31F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1123	GHW

<b>Client Sample ID:</b> HHES 32F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1125	GHW

<b>Client Sample ID:</b> HHES 33F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1126	GHW

<b>Client Sample ID:</b> HHES 34F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1130	GHW





Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 35F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1131	GHW

<b>Client Sample ID:</b> HHES 36F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1133	GHW

<b>Client Sample ID:</b> HHES 37 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1134	GHW

<b>Client Sample ID:</b> HHES 38 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1135	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 41F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1139	GHW

<b>Client Sample ID:</b> HHES 45F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1141	GHW

<b>Client Sample ID:</b> HHES 46 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1142	GHW

<b>Client Sample ID:</b> HHES 47 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1146	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 49F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1147	GHW

<b>Client Sample ID:</b> HHES 50F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1149	GHW

<b>Client Sample ID:</b> HHES 51F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1150	GHW

<b>Client Sample ID:</b> HHES 52F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1151	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 53F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1153	GHW

<b>Client Sample ID:</b> HHES 54F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1157	GHW

<b>Client Sample ID:</b> HHES 55 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1204	GHW

<b>Client Sample ID:</b> HHES 56F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1205	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 57F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1206	GHW

<b>Client Sample ID:</b> HHES 58F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1208	GHW

<b>Client Sample ID:</b> HHES 59F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1209	GHW

<b>Client Sample ID:</b> HHES 60F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-52	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1210	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 61F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-53	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1212	GHW

<b>Client Sample ID:</b> HHES 62F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-54	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1213	GHW

<b>Client Sample ID:</b> HHES 63F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1214	GHW

<b>Client Sample ID:</b> HHES 64F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1218	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 65F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1222	GHW

<b>Client Sample ID:</b> HHES 66F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1224	GHW

<b>Client Sample ID:</b> HHES 67 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1225	GHW

<b>Client Sample ID:</b> HHES 68F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1226	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 69F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1228	GHW

<b>Client Sample ID:</b> HHES 70F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-62	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1229	GHW

<b>Client Sample ID:</b> HHES 71F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-63	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1231	GHW

<b>Client Sample ID:</b> HHES 72F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-64	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1235	GHW





Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 73F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-65	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1236	GHW

<b>Client Sample ID:</b> HHES 74F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-66	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1240	GHW

<b>Client Sample ID:</b> HHES 75F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-67	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1244	GHW

<b>Client Sample ID:</b> HHES 76F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-68	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1245	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 77F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-69	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1247	GHW

<b>Client Sample ID:</b> HHES 78 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-70	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1251	GHW

<b>Client Sample ID:</b> HHES 79 DF/C C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-71	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1252	GHW

<b>Client Sample ID:</b> HHES 80F CC/B C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/26/2019 5:11
<b>Lab Sample ID:</b> 19D0396-72	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1254	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 1 IM C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-73	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1255	GHW

<b>Client Sample ID:</b> HHES 2 KS C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-74	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	3.8	20.0	1.0	ppb		04/04/19 1329	04/05/19 1256	GHW

<b>Client Sample ID:</b> HHES 3BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-75	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1258	GHW

<b>Client Sample ID:</b> HHES 4BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-76	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1259	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 6S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-77	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1303	GHW

<b>Client Sample ID:</b> HHES 7S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-78	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1307	GHW

<b>Client Sample ID:</b> HHES 8S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-79	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1308	GHW

<b>Client Sample ID:</b> HHES 9S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-80	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1310	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 10S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-81	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1311	GHW

<b>Client Sample ID:</b> HHES 11S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-82	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1313	GHW

<b>Client Sample ID:</b> HHES 12S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-83	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1314	GHW

<b>Client Sample ID:</b> HHES 13S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-84	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1315	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 14S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-85	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1329	04/05/19 1317	GHW

<b>Client Sample ID:</b> HHES 15S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-86	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1340	GHW

<b>Client Sample ID:</b> HHES 16BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-87	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1344	GHW

<b>Client Sample ID:</b> HHES 17S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-88	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1345	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 18S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-89	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1347	GHW

<b>Client Sample ID:</b> HHES 19S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-90	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1348	GHW

<b>Client Sample ID:</b> HHES 20S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-91	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1350	GHW

<b>Client Sample ID:</b> HHES 21S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-92	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1354	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 22S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-93	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1355	GHW

<b>Client Sample ID:</b> HHES 23S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-94	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1356	GHW

<b>Client Sample ID:</b> HHES 24S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-95	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1358	GHW

<b>Client Sample ID:</b> HHES 25S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-96	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1359	GHW





Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 26BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-97	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1403	GHW

<b>Client Sample ID:</b> HHES 27S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-98	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1405	GHW

<b>Client Sample ID:</b> HHES 28S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-99	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1406	GHW

<b>Client Sample ID:</b> HHES 29S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1410	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 30S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1411	GHW

<b>Client Sample ID:</b> HHES 31S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1413	GHW

<b>Client Sample ID:</b> HHES 32S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AD	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1414	GHW

<b>Client Sample ID:</b> HHES 33S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AE	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1416	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 34S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1417	GHW

<b>Client Sample ID:</b> HHES 35S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AG	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1421	GHW

<b>Client Sample ID:</b> HHES 36S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AH	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1428	GHW

<b>Client Sample ID:</b> HHES 37BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AI	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1429	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 39 TL C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AJ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1430	GHW

<b>Client Sample ID:</b> HHES 40 OT.7 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AK	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1432	GHW

<b>Client Sample ID:</b> HHES 41S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AL	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1433	GHW

<b>Client Sample ID:</b> HHES 42 NO C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AM	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1434	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 43 OT.2 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AN	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.1	20.0	1.0	ppb		04/04/19 1341	04/05/19 1436	GHW

<b>Client Sample ID:</b> HHES 44 CR C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AO	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1437	GHW

<b>Client Sample ID:</b> HHES 45S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AP	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1438	GHW

<b>Client Sample ID:</b> HHES 47BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AQ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1442	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 48 TL C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AR	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1446	GHW

<b>Client Sample ID:</b> HHES 49S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AS	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1448	GHW

<b>Client Sample ID:</b> HHES 50S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AT	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1449	GHW

<b>Client Sample ID:</b> HHES 51S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AU	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1450	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 52S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AV	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1452	GHW

<b>Client Sample ID:</b> HHES 53S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AW	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1453	GHW

<b>Client Sample ID:</b> HHES 54S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AX	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1454	GHW

<b>Client Sample ID:</b> HHES 55BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AY	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1458	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 56S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-AZ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1500	GHW

<b>Client Sample ID:</b> HHES 57S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1513	GHW

<b>Client Sample ID:</b> HHES 58S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1517	GHW

<b>Client Sample ID:</b> HHES 59S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1519	GHW





Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 60S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BD	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1520	GHW

<b>Client Sample ID:</b> HHES 61S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BE	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1524	GHW

<b>Client Sample ID:</b> HHES 62S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1525	GHW

<b>Client Sample ID:</b> HHES 63S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BG	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1527	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 64S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BH	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1528	GHW

<b>Client Sample ID:</b> HHES 65S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BI	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1529	GHW

<b>Client Sample ID:</b> HHES 66S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BJ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1531	GHW

<b>Client Sample ID:</b> HHES 67BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BK	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1532	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 68S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BL	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1536	GHW

<b>Client Sample ID:</b> HHES 69S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BM	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1540	GHW

<b>Client Sample ID:</b> HHES 70S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BN	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1541	GHW

<b>Client Sample ID:</b> HHES 71S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BO	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1543	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 72S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BP	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1544	GHW

<b>Client Sample ID:</b> HHES 73S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BQ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1545	GHW

<b>Client Sample ID:</b> HHES 74S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BR	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1547	GHW

<b>Client Sample ID:</b> HHES 75S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BS	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1548	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

<b>Client Sample ID:</b> HHES 76S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BT	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1549	GHW

<b>Client Sample ID:</b> HHES 77S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BU	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1556	GHW

<b>Client Sample ID:</b> HHES 79BW OT.1 C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BV	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1600	GHW

<b>Client Sample ID:</b> HHES 80S CC/S C	<b>Collected By:</b> Jeffrey Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 03/27/2019 5:08
<b>Lab Sample ID:</b> 19D0396-BW	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1601	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19D0396

Client Sample ID:	HHES 81 OT.5 C	Collected By:	Jeffrey Klenk
Sample Matrix:	Drinking Water	Collection Date:	03/27/2019 5:08
Lab Sample ID:	19D0396-BX		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1603	GHW

Client Sample ID:	HHES 82 OT.5 C	Collected By:	Jeffrey Klenk
Sample Matrix:	Drinking Water	Collection Date:	03/27/2019 5:08
Lab Sample ID:	19D0396-BY		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		04/04/19 1341	04/05/19 1604	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:



Megan Greenfield  
 Customer Relationship Coordinator  
 Reported: 04/08/2019 16:17