



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

KCI Technologies

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Hollifield Station Elementary School

Project / PO Number: N/A
Received: 05/13/2019
Reported: 05/20/2019

Analytical Testing Parameters

Table with client sample details: Client Sample ID: HSES 3 DF/C, Sample Matrix: Drinking Water, Lab Sample ID: 19E0848-01, Collected By: Jeff Klenk, Collection Date: 05/07/2019 5:03

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with lead analysis results: Lead, Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/17/19 0948, Analyzed 05/17/19 1112, Analyst GHW

Table with client sample details: Client Sample ID: HSES 4 DF/C, Sample Matrix: Drinking Water, Lab Sample ID: 19E0848-02, Collected By: Jeff Klenk, Collection Date: 05/07/2019 5:03

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with lead analysis results: Lead, Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/17/19 0948, Analyzed 05/17/19 1116, Analyst GHW

Table with client sample details: Client Sample ID: HSES 5 DF/C, Sample Matrix: Drinking Water, Lab Sample ID: 19E0848-03, Collected By: Jeff Klenk, Collection Date: 05/07/2019 5:03

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with lead analysis results: Lead, Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/17/19 0948, Analyzed 05/17/19 1117, Analyst GHW

Table with client sample details: Client Sample ID: HSES 6F CC/B, Sample Matrix: Drinking Water, Lab Sample ID: 19E0848-04, Collected By: Jeff Klenk, Collection Date: 05/07/2019 5:03

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with lead analysis results: Lead, Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/17/19 0948, Analyzed 05/17/19 1119, Analyst GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 7F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1120	GHW

Client Sample ID: HSES 8F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1121	GHW

Client Sample ID: HSES 10F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1125	GHW

Client Sample ID: HSES 11F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1127	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 12 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1141	GHW

Client Sample ID: HSES 13F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		05/17/19 0948	05/17/19 1142	GHW

Client Sample ID: HSES 15F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1143	GHW

Client Sample ID: HSES 16F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1147	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 18F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1149	GHW

Client Sample ID: HSES 19F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1150	GHW

Client Sample ID: HSES 20F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.9	20.0	1.0	ppb		05/17/19 0948	05/17/19 1154	GHW

Client Sample ID: HSES 21F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1155	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 22F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1157	GHW

Client Sample ID: HSES 24F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1158	GHW

Client Sample ID: HSES 25F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1159	GHW

Client Sample ID: HSES 29 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1201	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 30 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1205	GHW

Client Sample ID: HSES 35F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1211	GHW

Client Sample ID: HSES 36F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1213	GHW

Client Sample ID: HSES 38F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1214	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 39F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1215	GHW

Client Sample ID: HSES 40F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		05/17/19 0948	05/17/19 1217	GHW

Client Sample ID: HSES 41 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1218	GHW

Client Sample ID: HSES 42F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1219	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 43F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1221	GHW

Client Sample ID: HSES 44F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1222	GHW

Client Sample ID: HSES 46F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1226	GHW

Client Sample ID: HSES 47F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1230	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 48 DF/C	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1231	GHW

Client Sample ID: HSES 49F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1233	GHW

Client Sample ID: HSES 50F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1234	GHW

Client Sample ID: HSES 51F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1235	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 52F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		05/17/19 0948	05/17/19 1237	GHW

Client Sample ID: HSES 53F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1238	GHW

Client Sample ID: HSES 54F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1242	GHW

Client Sample ID: HSES 57F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1243	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 58F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1247	GHW

Client Sample ID: HSES 59F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1251	GHW

Client Sample ID: HSES 60F CC/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1253	GHW

Client Sample ID: HSES 61F DF/B	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/07/2019 5:03
Lab Sample ID: 19E0848-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1254	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 1 KS	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.7	20.0	1.0	ppb		05/17/19 0948	05/17/19 1258	GHW

Client Sample ID: HSES 2 IM	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.1	20.0	1.0	ppb		05/16/19 0958	05/16/19 1558	GHW

Client Sample ID: HSES 6S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1259	GHW

Client Sample ID: HSES 7S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1301	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 8S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1302	GHW

Client Sample ID: HSES 9 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1304	GHW

Client Sample ID: HSES 10S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1305	GHW

Client Sample ID: HSES 11S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-52	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1306	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 13S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-53	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1310	GHW

Client Sample ID: HSES 14 OT.7	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-54	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1314	GHW

Client Sample ID: HSES 15S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1316	GHW

Client Sample ID: HSES 16S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1317	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 17 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1318	GHW

Client Sample ID: HSES 18S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1320	GHW

Client Sample ID: HSES 19S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1321	GHW

Client Sample ID: HSES 20S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 0948	05/17/19 1322	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 21S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1330	GHW

Client Sample ID: HSES 22S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-62	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1334	GHW

Client Sample ID: HSES 23 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-63	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1336	GHW

Client Sample ID: HSES 24S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-64	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1337	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 25S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-65	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1339	GHW

Client Sample ID: HSES 26 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-66	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1340	GHW

Client Sample ID: HSES 27 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-67	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1344	GHW

Client Sample ID: HSES 28 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-68	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1345	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 31 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-69	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1347	GHW

Client Sample ID: HSES 32 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-70	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1348	GHW

Client Sample ID: HSES 33 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-71	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1349	GHW

Client Sample ID: HSES 34 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-72	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1354	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 35S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-73	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1355	GHW

Client Sample ID: HSES 36S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-74	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1356	GHW

Client Sample ID: HSES 37 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-75	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1400	GHW

Client Sample ID: HSES 38S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-76	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1402	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 39S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-77	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1403	GHW

Client Sample ID: HSES 40S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-78	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1404	GHW

Client Sample ID: HSES 42S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-79	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1406	GHW

Client Sample ID: HSES 43S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-80	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1407	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 44S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-81	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1411	GHW

Client Sample ID: HSES 45 CR	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-82	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1418	GHW

Client Sample ID: HSES 46S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-83	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1419	GHW

Client Sample ID: HSES 47S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-84	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1421	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 49S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-85	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1422	GHW

Client Sample ID: HSES 50S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-86	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1423	GHW

Client Sample ID: HSES 51S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-87	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1425	GHW

Client Sample ID: HSES 52S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-88	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1426	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 53S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-89	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1428	GHW

Client Sample ID: HSES 54S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-90	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1429	GHW

Client Sample ID: HSES 55 TL	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-91	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1433	GHW

Client Sample ID: HSES 56 OT.2	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-92	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.9	20.0	1.0	ppb		05/17/19 1003	05/17/19 1437	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID: HSES 57S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-93	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1438	GHW

Client Sample ID: HSES 58S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-94	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1440	GHW

Client Sample ID: HSES 59S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-95	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1441	GHW

Client Sample ID: HSES 60S CC/S	Collected By: Jeff Klenk
Sample Matrix: Drinking Water	Collection Date: 05/08/2019 5:03
Lab Sample ID: 19E0848-96	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1443	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Client Sample ID:	HSES 61S NO	Collected By:	Jeff Klenk
Sample Matrix:	Drinking Water	Collection Date:	05/08/2019 5:03
Lab Sample ID:	19E0848-97		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1444	GHW

Client Sample ID:	HSES 5BW OT.1	Collected By:	Jeff Klenk
Sample Matrix:	Drinking Water	Collection Date:	05/08/2019 5:03
Lab Sample ID:	19E0848-98		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1445	GHW

Client Sample ID:	HSES 30BW OT.1	Collected By:	Jeff Klenk
Sample Matrix:	Drinking Water	Collection Date:	05/08/2019 5:03
Lab Sample ID:	19E0848-99		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1449	GHW

Client Sample ID:	HSES 41BW OT.1	Collected By:	Jeff Klenk
Sample Matrix:	Drinking Water	Collection Date:	05/08/2019 5:03
Lab Sample ID:	19E0848-AA		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/17/19 1003	05/17/19 1451	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0848

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "M Greenfield", written over a light gray rectangular background.

Megan Greenfield

Customer Relationship Coordinator

Reported: 05/20/2019 17:21