



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0849

KCI Technologies

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Lisbon Elementary School

Project / PO Number: N/A
Received: 05/13/2019
Reported: 05/16/2019

Analytical Testing Parameters

Table with client sample details: Client Sample ID: LIES 3FA CC/B, Sample Matrix: Drinking Water, Lab Sample ID: 19E0849-01, Collected By: Jeff Klenk, Collection Date: 05/03/2019 5:20

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result 10.1, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/15/19 1655, Analyzed 05/15/19 2034, Analyst GHW

Table with client sample details: Client Sample ID: LIES 3FB CC/B, Sample Matrix: Drinking Water, Lab Sample ID: 19E0849-02, Collected By: Jeff Klenk, Collection Date: 05/03/2019 5:20

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result 2.4, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/15/19 1655, Analyzed 05/15/19 2035, Analyst GHW

Table with client sample details: Client Sample ID: LIES 27 DF/C, Sample Matrix: Drinking Water, Lab Sample ID: 19E0849-03, Collected By: Jeff Klenk, Collection Date: 05/03/2019 5:20

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result 6.2, Limit(s) 20.0, RL 1.0, Units ppb, Prepared 05/15/19 1655, Analyzed 05/15/19 2037, Analyst GHW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0849

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "M Greenfield", is written over a light gray rectangular background.

Megan Greenfield

Customer Relationship Coordinator

Reported: 05/16/2019 17:06