



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

KCI Technologies

Project Name: Mt. Hebron High School

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project / PO Number: N/A
Received: 05/13/2019
Reported: 05/22/2019

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (MHHS-01 KS C, Drinking Water, 19E0850-01). Includes Collected By: John Adams and Collection Date: 05/11/2019 5:13.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 05/20/19 1144, Analyzed 05/21/19 1001, Analyst GHW.

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (MHHS-02 KS C, Drinking Water, 19E0850-02). Includes Collected By: John Adams and Collection Date: 05/11/2019 5:17.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result 1.4, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 05/20/19 1144, Analyzed 05/21/19 1005, Analyst GHW.

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (MHHS-03 IM C, Drinking Water, 19E0850-03). Includes Collected By: John Adams and Collection Date: 05/11/2019 7:20.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 05/20/19 1144, Analyzed 05/21/19 1006, Analyst GHW.

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (MHHS-04 DF C, Drinking Water, 19E0850-04). Includes Collected By: John Adams and Collection Date: 05/11/2019 5:22.

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table row for Lead: Result <1.0, Limit(s) 20.0, RL 1.0, Units ppb, Note, Prepared 05/20/19 1144, Analyzed 05/21/19 1007, Analyst GHW.



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-05 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:23
Lab Sample ID: 19E0850-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1009	GHW

Client Sample ID: MHHS-06 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:26
Lab Sample ID: 19E0850-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1010	GHW

Client Sample ID: MHHS-07 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:27
Lab Sample ID: 19E0850-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1014	GHW

Client Sample ID: MHHS-08 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:28
Lab Sample ID: 19E0850-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1015	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-09 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:29
Lab Sample ID: 19E0850-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1017	GHW

Client Sample ID: MHHS-10 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:31
Lab Sample ID: 19E0850-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1018	GHW

Client Sample ID: MHHS-11 IM C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:32
Lab Sample ID: 19E0850-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/21/19 1513	05/22/19 1056	GHW

Client Sample ID: MHHS-12 IM C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:34
Lab Sample ID: 19E0850-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/21/19 1513	05/22/19 1058	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-13 IM C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:35
Lab Sample ID: 19E0850-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1019	GHW

Client Sample ID: MHHS-14 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:36
Lab Sample ID: 19E0850-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1023	GHW

Client Sample ID: MHHS-15 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:39
Lab Sample ID: 19E0850-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1025	GHW

Client Sample ID: MHHS-16 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:40
Lab Sample ID: 19E0850-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1026	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-17 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:42
Lab Sample ID: 19E0850-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1030	GHW

Client Sample ID: MHHS-18 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:43
Lab Sample ID: 19E0850-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1031	GHW

Client Sample ID: MHHS-19 CR C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:45
Lab Sample ID: 19E0850-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1033	GHW

Client Sample ID: MHHS-20 CR C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:47
Lab Sample ID: 19E0850-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		05/20/19 1144	05/21/19 1034	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-21 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:48
Lab Sample ID: 19E0850-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1035	GHW

Client Sample ID: MHHS-22 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:49
Lab Sample ID: 19E0850-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1037	GHW

Client Sample ID: MHHS-23 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:51
Lab Sample ID: 19E0850-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		05/20/19 1144	05/21/19 1041	GHW

Client Sample ID: MHHS-24 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:56
Lab Sample ID: 19E0850-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1047	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-25 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:57
Lab Sample ID: 19E0850-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1049	GHW

Client Sample ID: MHHS-26 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:53
Lab Sample ID: 19E0850-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1050	GHW

Client Sample ID: MHHS-27 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:54
Lab Sample ID: 19E0850-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1051	GHW

Client Sample ID: MHHS-28 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:00
Lab Sample ID: 19E0850-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1053	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-29 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:00
Lab Sample ID: 19E0850-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1054	GHW

Client Sample ID: MHHS-30 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:04
Lab Sample ID: 19E0850-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1055	GHW

Client Sample ID: MHHS-31 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:04
Lab Sample ID: 19E0850-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1057	GHW

Client Sample ID: MHHS-32 TL C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:07
Lab Sample ID: 19E0850-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1058	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-33 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:08
Lab Sample ID: 19E0850-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1102	GHW

Client Sample ID: MHHS-34 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:08
Lab Sample ID: 19E0850-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1106	GHW

Client Sample ID: MHHS-35 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:10
Lab Sample ID: 19E0850-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1107	GHW

Client Sample ID: MHHS-36 HE C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:12
Lab Sample ID: 19E0850-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		05/20/19 1144	05/21/19 1109	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-37 HE C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:12
Lab Sample ID: 19E0850-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.4	20.0	1.0	ppb		05/20/19 1144	05/21/19 1110	GHW

Client Sample ID: MHHS-38 HE C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:13
Lab Sample ID: 19E0850-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		05/20/19 1144	05/21/19 1111	GHW

Client Sample ID: MHHS-39 HE C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:13
Lab Sample ID: 19E0850-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		05/20/19 1144	05/21/19 1113	GHW

Client Sample ID: MHHS-40 HE C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:14
Lab Sample ID: 19E0850-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.1	20.0	1.0	ppb		05/20/19 1144	05/21/19 1114	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-41 HE C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:14
Lab Sample ID: 19E0850-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.1	20.0	1.0	ppb		05/20/19 1144	05/21/19 1118	GHW

Client Sample ID: MHHS-42 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:26
Lab Sample ID: 19E0850-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		05/20/19 1144	05/21/19 1120	GHW

Client Sample ID: MHHS-43 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:26
Lab Sample ID: 19E0850-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		05/20/19 1144	05/21/19 1124	GHW

Client Sample ID: MHHS-44 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:27
Lab Sample ID: 19E0850-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1128	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-45 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:28
Lab Sample ID: 19E0850-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1129	GHW

Client Sample ID: MHHS-46 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:30
Lab Sample ID: 19E0850-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.4	20.0	1.0	ppb		05/20/19 1144	05/21/19 1130	GHW

Client Sample ID: MHHS-47 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:30
Lab Sample ID: 19E0850-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		05/20/19 1144	05/21/19 1134	GHW

Client Sample ID: MHHS-48 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:33
Lab Sample ID: 19E0850-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.7	20.0	1.0	ppb		05/20/19 1144	05/21/19 1136	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-49 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:33
Lab Sample ID: 19E0850-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		05/20/19 1144	05/21/19 1137	GHW

Client Sample ID: MHHS-50 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:35
Lab Sample ID: 19E0850-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1138	GHW

Client Sample ID: MHHS-51 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:41
Lab Sample ID: 19E0850-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1140	GHW

Client Sample ID: MHHS-52 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:51
Lab Sample ID: 19E0850-52	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
-----------------------------------------	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1141	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-53 DF C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:51
Lab Sample ID: 19E0850-53	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1142	GHW

Client Sample ID: MHHS-54 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:54
Lab Sample ID: 19E0850-54	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		05/20/19 1144	05/21/19 1146	GHW

Client Sample ID: MHHS-55 TL C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:55
Lab Sample ID: 19E0850-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		05/20/19 1144	05/21/19 1150	GHW

Client Sample ID: MHHS-56 NO C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 6:59
Lab Sample ID: 19E0850-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	24.1	20.0	1.0	ppb		05/20/19 1144	05/21/19 1152	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-57 NO C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 7:16
Lab Sample ID: 19E0850-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/20/19 1144	05/21/19 1153	GHW

Client Sample ID: MHHS-58 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 7:06
Lab Sample ID: 19E0850-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.9	20.0	1.0	ppb		05/20/19 1144	05/21/19 1154	GHW

Client Sample ID: MHHS-59 IM C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 7:08
Lab Sample ID: 19E0850-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		05/21/19 1513	05/22/19 1059	GHW

Client Sample ID: MHHS-60 KS C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 5:19
Lab Sample ID: 19E0850-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	13.3	20.0	1.0	ppb		05/20/19 1144	05/21/19 1156	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E0850

Client Sample ID: MHHS-61 OT C	Collected By: John Adams
Sample Matrix: Drinking Water	Collection Date: 05/11/2019 7:08
Lab Sample ID: 19E0850-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		05/20/19 1144	05/21/19 1157	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:



Megan Greenfield
 Customer Relationship Coordinator
 Reported: 05/22/2019 16:12