



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

KCI Technologies

Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Triadelphia Ridge Elementary

School
Project / PO Number: N/A
Received: 05/29/2019
Reported: 05/31/2019

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (TRES 2 First Draw DF/C, Drinking Water, 19E1508-01, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (05/30/19 1314), Analyzed (05/30/19 1511), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (TRES 3 First Draw DF/C, Drinking Water, 19E1508-02, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (05/30/19 1314), Analyzed (05/30/19 1516), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (TRES 4 First Draw DF/C, Drinking Water, 19E1508-03, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (05/30/19 1314), Analyzed (05/30/19 1517), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (TRES 5F First Draw CC/B, Drinking Water, 19E1508-04, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (3.2), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (05/30/19 1314), Analyzed (05/30/19 1518), Analyst (GHW)



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 6F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		05/30/19 1314	05/30/19 1520	GHW

<b>Client Sample ID:</b> TRES 7F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		05/30/19 1314	05/30/19 1521	GHW

<b>Client Sample ID:</b> TRES 9F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		05/30/19 1314	05/30/19 1525	GHW

<b>Client Sample ID:</b> TRES 10F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	2.2	20.0	1.0	ppb		05/30/19 1314	05/30/19 1526	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 11 First Draw DF/C	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1528	GHW

<b>Client Sample ID:</b> TRES 12F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	3.2	20.0	1.0	ppb		05/30/19 1314	05/30/19 1529	GHW

<b>Client Sample ID:</b> TRES 14F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1531	GHW

<b>Client Sample ID:</b> TRES 15F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1535	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 17F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		05/30/19 1314	05/30/19 1536	GHW

<b>Client Sample ID:</b> TRES 18F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		05/30/19 1314	05/30/19 1537	GHW

<b>Client Sample ID:</b> TRES 19F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		05/30/19 1314	05/30/19 1541	GHW

<b>Client Sample ID:</b> TRES 20F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1543	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 21F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		05/30/19 1314	05/30/19 1544	GHW

<b>Client Sample ID:</b> TRES 23F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1546	GHW

<b>Client Sample ID:</b> TRES 24F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		05/30/19 1314	05/30/19 1547	GHW

<b>Client Sample ID:</b> TRES 25F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		05/30/19 1314	05/30/19 1548	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 26 First Draw DF/C	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1552	GHW

<b>Client Sample ID:</b> TRES 27F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1559	GHW

<b>Client Sample ID:</b> TRES 28F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.4	20.0	1.0	ppb		05/30/19 1314	05/30/19 1600	GHW

<b>Client Sample ID:</b> TRES 30F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.6	20.0	1.0	ppb		05/30/19 1314	05/30/19 1602	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 31F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		05/30/19 1314	05/30/19 1603	GHW

<b>Client Sample ID:</b> TRES 32F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	3.3	20.0	1.0	ppb		05/30/19 1314	05/30/19 1604	GHW

<b>Client Sample ID:</b> TRES 33F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		05/30/19 1314	05/30/19 1606	GHW

<b>Client Sample ID:</b> TRES 34F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		05/30/19 1314	05/30/19 1607	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 36F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		05/30/19 1314	05/30/19 1608	GHW

<b>Client Sample ID:</b> TRES 37F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		05/30/19 1314	05/30/19 1610	GHW

<b>Client Sample ID:</b> TRES 38 First Draw DF/C	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-31	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		05/30/19 1314	05/30/19 1614	GHW

<b>Client Sample ID:</b> TRES 39F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	2.1	20.0	1.0	ppb		05/30/19 1314	05/30/19 1618	GHW





Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 40F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	6.7	20.0	1.0	ppb		05/30/19 1314	05/30/19 1619	GHW

<b>Client Sample ID:</b> TRES 42F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1620	GHW

<b>Client Sample ID:</b> TRES 43F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1622	GHW

<b>Client Sample ID:</b> TRES 44F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1623	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 46F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.7	20.0	1.0	ppb		05/30/19 1314	05/30/19 1624	GHW

<b>Client Sample ID:</b> TRES 47F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	3.5	20.0	1.0	ppb		05/30/19 1314	05/30/19 1626	GHW

<b>Client Sample ID:</b> TRES 48F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-39	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	3.1	20.0	1.0	ppb		05/30/19 1314	05/30/19 1630	GHW

<b>Client Sample ID:</b> TRES 49F First Draw CC/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	4.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1631	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 52F First Draw DF/B	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/14/2019 5:15
<b>Lab Sample ID:</b> 19E1508-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	2.7	20.0	1.0	ppb		05/30/19 1314	05/30/19 1635	GHW

<b>Client Sample ID:</b> TRES 1 First Draw KS	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	2.9	20.0	1.0	ppb		05/30/19 1314	05/30/19 1639	GHW

<b>Client Sample ID:</b> TRES 5S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.6	20.0	1.0	ppb		05/30/19 1314	05/30/19 1640	GHW

<b>Client Sample ID:</b> TRES 6S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1642	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 7S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		05/30/19 1314	05/30/19 1646	GHW

<b>Client Sample ID:</b> TRES 8 First Draw CR	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	2.7	20.0	1.0	ppb		05/30/19 1314	05/30/19 1647	GHW

<b>Client Sample ID:</b> TRES 9S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1648	GHW

<b>Client Sample ID:</b> TRES 10S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		05/30/19 1314	05/30/19 1650	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 12S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		05/30/19 1314	05/30/19 1651	GHW

<b>Client Sample ID:</b> TRES 13 First Draw OT.7	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	2.3	20.0	1.0	ppb		05/30/19 1314	05/30/19 1652	GHW

<b>Client Sample ID:</b> TRES 14S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		05/30/19 1314	05/30/19 1654	GHW

<b>Client Sample ID:</b> TRES 15S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-52	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1658	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 16 First Draw CR	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-53	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	3.1	20.0	1.0	ppb		05/30/19 1314	05/30/19 1702	GHW

<b>Client Sample ID:</b> TRES 17S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-54	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1703	GHW

<b>Client Sample ID:</b> TRES 18S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1704	GHW

<b>Client Sample ID:</b> TRES 19S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1706	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 20S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1707	GHW

<b>Client Sample ID:</b> TRES 21S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1708	GHW

<b>Client Sample ID:</b> TRES 22 First Draw CR	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	2.4	20.0	1.0	ppb		05/30/19 1314	05/30/19 1710	GHW

<b>Client Sample ID:</b> TRES 23S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1314	05/30/19 1711	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 24S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1225	GHW

<b>Client Sample ID:</b> TRES 25S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-62	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1229	GHW

<b>Client Sample ID:</b> TRES 27S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-63	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.1	20.0	1.0	ppb		05/30/19 1404	05/31/19 1231	GHW

<b>Client Sample ID:</b> TRES 28S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-64	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1232	GHW





Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 29 First Draw CR	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-65	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	4.2	20.0	1.0	ppb		05/30/19 1404	05/31/19 1233	GHW

<b>Client Sample ID:</b> TRES 30S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-66	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		05/30/19 1404	05/31/19 1235	GHW

<b>Client Sample ID:</b> TRES 31S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-67	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1239	GHW

<b>Client Sample ID:</b> TRES 32S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-68	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1240	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 33S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-69	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.2	20.0	1.0	ppb		05/30/19 1404	05/31/19 1241	GHW

<b>Client Sample ID:</b> TRES 34S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-70	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.1	20.0	1.0	ppb		05/30/19 1404	05/31/19 1243	GHW

<b>Client Sample ID:</b> TRES 35 First Draw CR	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-71	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	2.7	20.0	1.0	ppb		05/30/19 1404	05/31/19 1244	GHW

<b>Client Sample ID:</b> TRES 36S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-72	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1248	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 37S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-73	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1250	GHW

<b>Client Sample ID:</b> TRES 39S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-74	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.6	20.0	1.0	ppb		05/30/19 1404	05/31/19 1251	GHW

<b>Client Sample ID:</b> TRES 40S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-75	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1255	GHW

<b>Client Sample ID:</b> TRES 41 First Draw CR	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-76	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	3.6	20.0	1.0	ppb		05/30/19 1404	05/31/19 1256	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 42S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-77	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1258	GHW

<b>Client Sample ID:</b> TRES 43S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-78	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1259	GHW

<b>Client Sample ID:</b> TRES 44S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-79	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		05/30/19 1404	05/31/19 1301	GHW

<b>Client Sample ID:</b> TRES 45 First Draw CR	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-80	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	3.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1302	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 46S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-81	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1306	GHW

<b>Client Sample ID:</b> TRES 47S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-82	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		05/30/19 1404	05/31/19 1313	GHW

<b>Client Sample ID:</b> TRES 48S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-83	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	3.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1314	GHW

<b>Client Sample ID:</b> TRES 49S First Draw CC/S	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-84	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

<b>Method:</b> EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		05/30/19 1404	05/31/19 1315	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

<b>Client Sample ID:</b> TRES 50 First Draw TL	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-85	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1317	GHW

<b>Client Sample ID:</b> TRES 51 First Draw OT.2	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-86	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<b>332</b>	20.0	1.0	ppb		05/30/19 1412	05/31/19 1035	GHW

<b>Client Sample ID:</b> TRES 52S First Draw NO	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-87	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	1.3	20.0	1.0	ppb		05/30/19 1404	05/31/19 1318	GHW

<b>Client Sample ID:</b> TRES 3BW First Draw OT.1	<b>Collected By:</b> Jeff Klenk
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 05/15/2019 5:15
<b>Lab Sample ID:</b> 19E1508-88	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.2/EPA 200.8</b>								
Lead	<1.0	20.0	1.0	ppb		05/30/19 1404	05/31/19 1320	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

19E1508

**Report Comments**

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

**Reviewed and Approved By:**

Evelyn Shinas  
Customer Relationship Coordinator  
Reported: 05/31/2019 15:20